

Sample Summary

Partner Engineering & Science

Job No: JC38837

Goetz Middle School, 835 Patterson Road, Jackson, NJ

Sample Number	Collected		Received	Matrix		Client Sample ID
	Date	Time By		Code	Type	
JC38837-1	03/11/17	06:00 BT	03/13/17	DW	Drinking Water	CG-POE
JC38837-3	03/11/17	06:33 BT	03/13/17	DW	Drinking Water	CG-S-01
JC38837-5	03/11/17	06:10 BT	03/13/17	DW	Drinking Water	CG-WF-02
JC38837-7	03/11/17	06:42 BT	03/13/17	DW	Drinking Water	CG-S-03
JC38837-9	03/11/17	06:37 BT	03/13/17	DW	Drinking Water	CG-S-04
JC38837-11	03/11/17	06:57 BT	03/13/17	DW	Drinking Water	CG-WF-05
JC38837-13	03/11/17	07:01 BT	03/13/17	DW	Drinking Water	CG-WF-06
JC38837-15	03/11/17	06:48 BT	03/13/17	DW	Drinking Water	CG-S-07
JC38837-17	03/11/17	06:51 BT	03/13/17	DW	Drinking Water	CG-WF-08
JC38837-18	03/11/17	06:51 BT	03/13/17	DW	Drinking Water	CG-WF-08 FLUSH
JC38837-19	03/11/17	07:16 BT	03/13/17	DW	Drinking Water	CG-WF-09
JC38837-21	03/11/17	07:12 BT	03/13/17	DW	Drinking Water	CG-S-10
JC38837-23	03/11/17	07:30 BT	03/13/17	DW	Drinking Water	CG-S-11

Sample Summary (continued)

Partner Engineering & Science

Job No: JC38837

Goetz Middle School, 835 Patterson Road, Jackson, NJ

Sample Number	Collected		Received	Matrix		Client Sample ID
	Date	Time By		Code	Type	
JC38837-24	03/11/17	07:30 BT	03/13/17	DW	Drinking Water	CG-S-11 FLUSH
JC38837-25	03/11/17	07:35 BT	03/13/17	DW	Drinking Water	CG-WF-12
JC38837-27	03/11/17	07:39 BT	03/13/17	DW	Drinking Water	CG-WF-13
JC38837-29	03/11/17	07:43 BT	03/13/17	DW	Drinking Water	CG-WF-14
JC38837-31	03/11/17	07:46 BT	03/13/17	DW	Drinking Water	CG-WF-15
JC38837-33	03/11/17	07:56 BT	03/13/17	DW	Drinking Water	CG-S-16
JC38837-35	03/11/17	07:53 BT	03/13/17	DW	Drinking Water	CG-S-17
JC38837-37	03/11/17	08:04 BT	03/13/17	DW	Drinking Water	CG-WF-19
JC38837-38	03/11/17	08:04 BT	03/13/17	DW	Drinking Water	CG-WF-19 FLUSH
JC38837-39	03/11/17	08:11 BT	03/13/17	DW	Drinking Water	CG-S-20
JC38837-41	03/11/17	08:14 BT	03/13/17	DW	Drinking Water	CG-S-21
JC38837-42	03/11/17	08:14 BT	03/13/17	DW	Drinking Water	CG-S-21 FLUSH
JC38837-43	03/11/17	08:19 BT	03/13/17	DW	Drinking Water	CG-S-23

Sample Summary (continued)

Partner Engineering & Science

Job No: JC38837

Goetz Middle School, 835 Patterson Road, Jackson, NJ

Sample Number	Collected		Received	Matrix		Client Sample ID
	Date	Time By		Code	Type	
JC38837-45	03/11/17	08:22 BT	03/13/17	DW	Drinking Water	CG-S-24
JC38837-47	03/11/17	08:27 BT	03/13/17	DW	Drinking Water	CG-S-25
JC38837-49	03/11/17	07:59 BT	03/13/17	DW	Drinking Water	CG-WF-26
JC38837-51	03/11/17	07:22 BT	03/13/17	DW	Drinking Water	CG-S-27
JC38837-52	03/11/17	07:22 BT	03/13/17	DW	Drinking Water	CG-S-27 FLUSH
JC38837-53	03/11/17	07:08 BT	03/13/17	DW	Drinking Water	CG-WF-28
JC38837-54	03/11/17	07:08 BT	03/13/17	DW	Drinking Water	CG-WF-28 FLUSH
JC38837-55	03/11/17	06:16 BT	03/13/17	DW	Drinking Water	CG-S-29
JC38837-57	03/11/17	06:21 BT	03/13/17	DW	Drinking Water	CG-S-30
JC38837-58	03/11/17	06:21 BT	03/13/17	DW	Drinking Water	CG-S-30 FLUSH
JC38837-59	03/11/17	06:25 BT	03/13/17	DW	Drinking Water	CG-S-31
JC38837-60	03/11/17	06:25 BT	03/13/17	DW	Drinking Water	CG-S-31 FLUSH
JC38837-61	03/11/17	06:06 BT	03/13/17	DW	Drinking Water	CG-S-32

Sample Summary
(continued)

Partner Engineering & Science

Job No: JC38837

Goetz Middle School, 835 Patterson Road, Jackson, NJ

Sample Number	Collected		Received	Matrix		Client Sample ID
	Date	Time By		Code	Type	
JC38837-62	03/11/17	06:06 BT	03/13/17	DW	Drinking Water	CG-S-32 FLUSH
JC38837-63	03/11/17	08:33 BT	03/13/17	DW	Drinking Water	CG-WF-33
JC38837-65	03/11/17	08:38 BT	03/13/17	DW	Drinking Water	CG-WF-34
JC38837-67	03/11/17	10:30 BT	03/13/17	DW	Drinking Water FB	CG-FIELD BLANK
JC38837-68	03/11/17	08:43 BT	03/13/17	DW	Drinking Water	CG-WF-36
JC38837-70	03/11/17	08:46 BT	03/13/17	DW	Drinking Water	CG-S-37

Report of Analysis

Client Sample ID: CG-POE		Date Sampled: 03/11/17
Lab Sample ID: JC38837-1		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.0072	0.015	0.00050	mg/l	1	03/15/17	03/16/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41571

(2) Prep QC Batch: MP99257

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-S-01		Date Sampled: 03/11/17
Lab Sample ID: JC38837-3		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.0019	0.015	0.00050	mg/l	1	03/15/17	03/16/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41571

(2) Prep QC Batch: MP99257

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-WF-02		Date Sampled: 03/11/17
Lab Sample ID: JC38837-5		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00061	0.015	0.00050	mg/l	1	03/15/17	03/16/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41571

(2) Prep QC Batch: MP99257

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-S-03		Date Sampled: 03/11/17
Lab Sample ID: JC38837-7		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.0059	0.015	0.00050	mg/l	1	03/15/17	03/16/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41571

(2) Prep QC Batch: MP99257

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-S-04		Date Sampled: 03/11/17
Lab Sample ID: JC38837-9		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.0037	0.015	0.00050	mg/l	1	03/15/17	03/16/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41571

(2) Prep QC Batch: MP99257

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-WF-05		Date Sampled: 03/11/17
Lab Sample ID: JC38837-11		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.011	0.015	0.00050	mg/l	1	03/15/17	03/16/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41571

(2) Prep QC Batch: MP99257

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-WF-06		Date Sampled: 03/11/17
Lab Sample ID: JC38837-13		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.0039	0.015	0.00050	mg/l	1	03/15/17	03/16/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41571

(2) Prep QC Batch: MP99257

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-S-07		Date Sampled: 03/11/17
Lab Sample ID: JC38837-15		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.0050	0.015	0.00050	mg/l	1	03/15/17	03/16/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41571

(2) Prep QC Batch: MP99257

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-WF-08		Date Sampled: 03/11/17
Lab Sample ID: JC38837-17		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.017	0.015	0.00050	mg/l	1	03/15/17	03/16/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41571

(2) Prep QC Batch: MP99257

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-WF-08 FLUSH		Date Sampled: 03/11/17
Lab Sample ID: JC38837-18		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00585	0.015	0.00050	mg/l	1	03/17/17	03/17/17 MS	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41587

(2) Prep QC Batch: MP99306

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-WF-09		Date Sampled: 03/11/17
Lab Sample ID: JC38837-19		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.0055	0.015	0.00050	mg/l	1	03/15/17	03/16/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41571

(2) Prep QC Batch: MP99257

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-S-10		Date Sampled: 03/11/17
Lab Sample ID: JC38837-21		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.0026	0.015	0.00050	mg/l	1	03/15/17	03/15/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41571

(2) Prep QC Batch: MP99258

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-S-11		Date Sampled: 03/11/17
Lab Sample ID: JC38837-23		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.066	0.015	0.00050	mg/l	1	03/15/17	03/15/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41571

(2) Prep QC Batch: MP99258

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-S-11 FLUSH		Date Sampled: 03/11/17
Lab Sample ID: JC38837-24		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.0100	0.015	0.00050	mg/l	1	03/17/17	03/17/17 MS	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41587

(2) Prep QC Batch: MP99306

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-WF-12		Date Sampled: 03/11/17
Lab Sample ID: JC38837-25		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.0048	0.015	0.00050	mg/l	1	03/15/17	03/15/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41571

(2) Prep QC Batch: MP99258

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-WF-13		Date Sampled: 03/11/17
Lab Sample ID: JC38837-27		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.0064	0.015	0.00050	mg/l	1	03/15/17	03/15/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41571

(2) Prep QC Batch: MP99258

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-WF-14		Date Sampled: 03/11/17
Lab Sample ID: JC38837-29		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.010	0.015	0.00050	mg/l	1	03/15/17	03/15/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41571

(2) Prep QC Batch: MP99258

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-WF-15		Date Sampled: 03/11/17
Lab Sample ID: JC38837-31		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.0080	0.015	0.00050	mg/l	1	03/15/17	03/15/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41571

(2) Prep QC Batch: MP99258

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-S-16		Date Sampled: 03/11/17
Lab Sample ID: JC38837-33		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.0082	0.015	0.00050	mg/l	1	03/15/17	03/15/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41571

(2) Prep QC Batch: MP99258

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-S-17		Date Sampled: 03/11/17
Lab Sample ID: JC38837-35		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.0041	0.015	0.00050	mg/l	1	03/15/17	03/15/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41571

(2) Prep QC Batch: MP99258

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-WF-19		Date Sampled: 03/11/17
Lab Sample ID: JC38837-37		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.030	0.015	0.00050	mg/l	1	03/15/17	03/15/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41571

(2) Prep QC Batch: MP99258

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-WF-19 FLUSH		Date Sampled: 03/11/17
Lab Sample ID: JC38837-38		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00332	0.015	0.00050	mg/l	1	03/17/17	03/17/17 MS	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41587

(2) Prep QC Batch: MP99306

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-S-20		Date Sampled: 03/11/17
Lab Sample ID: JC38837-39		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.0026	0.015	0.00050	mg/l	1	03/15/17	03/15/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41571

(2) Prep QC Batch: MP99258

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-S-21		Date Sampled: 03/11/17
Lab Sample ID: JC38837-41		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.035	0.015	0.00050	mg/l	1	03/16/17	03/16/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41582

(2) Prep QC Batch: MP99259

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-S-21 FLUSH		Date Sampled: 03/11/17
Lab Sample ID: JC38837-42		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/17/17	03/17/17 MS	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41587

(2) Prep QC Batch: MP99316

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-S-23		Date Sampled: 03/11/17
Lab Sample ID: JC38837-43		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.0044	0.015	0.00050	mg/l	1	03/15/17	03/15/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41571

(2) Prep QC Batch: MP99259

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-S-24		Date Sampled: 03/11/17
Lab Sample ID: JC38837-45		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.014	0.015	0.00050	mg/l	1	03/15/17	03/15/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41571

(2) Prep QC Batch: MP99259

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-S-25		Date Sampled: 03/11/17
Lab Sample ID: JC38837-47		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00082	0.015	0.00050	mg/l	1	03/15/17	03/15/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41571

(2) Prep QC Batch: MP99259

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-WF-26		Date Sampled: 03/11/17
Lab Sample ID: JC38837-49		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.0016	0.015	0.00050	mg/l	1	03/15/17	03/15/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41571

(2) Prep QC Batch: MP99259

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-S-27		Date Sampled: 03/11/17
Lab Sample ID: JC38837-51		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.051	0.015	0.00050	mg/l	1	03/15/17	03/15/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41571

(2) Prep QC Batch: MP99259

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-S-27 FLUSH		Date Sampled: 03/11/17
Lab Sample ID: JC38837-52		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00143	0.015	0.00050	mg/l	1	03/17/17	03/17/17 MS	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41587

(2) Prep QC Batch: MP99316

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-WF-28		Date Sampled: 03/11/17
Lab Sample ID: JC38837-53		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.074	0.015	0.00050	mg/l	1	03/15/17	03/15/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41571

(2) Prep QC Batch: MP99259

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-WF-28 FLUSH		Date Sampled: 03/11/17
Lab Sample ID: JC38837-54		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00378	0.015	0.00050	mg/l	1	03/17/17	03/17/17 MS	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41587

(2) Prep QC Batch: MP99316

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-S-29		Date Sampled: 03/11/17
Lab Sample ID: JC38837-55		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.0047	0.015	0.00050	mg/l	1	03/15/17	03/15/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41571

(2) Prep QC Batch: MP99259

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-S-30		Date Sampled: 03/11/17
Lab Sample ID: JC38837-57		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.020	0.015	0.00050	mg/l	1	03/15/17	03/15/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41571

(2) Prep QC Batch: MP99259

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-S-30 FLUSH		Date Sampled: 03/11/17
Lab Sample ID: JC38837-58		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.000553	0.015	0.00050	mg/l	1	03/17/17	03/17/17 MS	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41587

(2) Prep QC Batch: MP99316

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-S-31		Date Sampled: 03/11/17
Lab Sample ID: JC38837-59		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.030	0.015	0.00050	mg/l	1	03/15/17	03/15/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41571

(2) Prep QC Batch: MP99259

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-S-31 FLUSH		Date Sampled: 03/11/17
Lab Sample ID: JC38837-60		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.000890	0.015	0.00050	mg/l	1	03/17/17	03/17/17 MS	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41587

(2) Prep QC Batch: MP99316

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-S-32		Date Sampled: 03/11/17
Lab Sample ID: JC38837-61		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.035	0.015	0.00050	mg/l	1	03/15/17	03/15/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41571

(2) Prep QC Batch: MP99260

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-S-32 FLUSH		Date Sampled: 03/11/17
Lab Sample ID: JC38837-62		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/17/17	03/17/17 MS	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41587

(2) Prep QC Batch: MP99316

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-WF-33		Date Sampled: 03/11/17
Lab Sample ID: JC38837-63		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00089	0.015	0.00050	mg/l	1	03/15/17	03/15/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41571

(2) Prep QC Batch: MP99260

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-WF-34		Date Sampled: 03/11/17
Lab Sample ID: JC38837-65		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00094	0.015	0.00050	mg/l	1	03/15/17	03/15/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41571

(2) Prep QC Batch: MP99260

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-FIELD BLANK		Date Sampled: 03/11/17
Lab Sample ID: JC38837-67		Date Received: 03/13/17
Matrix: DW - Drinking Water FB		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/15/17	03/15/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41571

(2) Prep QC Batch: MP99260

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-WF-36		Date Sampled: 03/11/17
Lab Sample ID: JC38837-68		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/16/17	03/16/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41582

(2) Prep QC Batch: MP99285

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

Report of Analysis

Client Sample ID: CG-S-37		Date Sampled: 03/11/17
Lab Sample ID: JC38837-70		Date Received: 03/13/17
Matrix: DW - Drinking Water		Percent Solids: n/a
Project: Goetz Middle School, 835 Patterson Road, Jackson, NJ		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.0023	0.015	0.00050	mg/l	1	03/16/17	03/16/17 MA	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA41582

(2) Prep QC Batch: MP99286

RL = Reporting Limit
MCL = Maximum Contamination Level (NJAC 7:10 11/04)



ACCUTEST

CHAIN OF CUSTODY

2235 Route 130, Dayton, NJ 08810
TEL: 732-329-0200 FAX: 732-329-3499/3480
www.accutest.com

FED-EX Tracking #	Bottle Order Control #
Accutest Quote #	Accutest Job # JC38837

Client / Reporting Information		Project Information										Requested Analysis (see TEST CODE sheet)										Matrix Codes																							
Company Name Partner Engineering and Science, Inc		Project Name Goetz Middle School										PBMS, TURBIDIMET										DW - Drinking Water GW - Ground Water WW - Water SW - Surface Water SO - Soil SL - Sludge SED - Sediment OI - Oil LIQ - Other Liquid AIR - Air SOL - Other Solid WP - Wipe FB - Field Blank EB - Equipment Blank RB - Rinse Blank TB - Trip Blank																							
Street Address 611 Industrial Way West		Street 835 Patterson Rd		Billing Information (if different from Report to)																			LAB USE ONLY A37																						
City Eatontown NJ		City Jackson NJ		State NJ		Company Name		Project #		Street Address																																			
Project Contact Matt Genna		Client Purchase Order #		City		State		Zip		Attention:																																			
Phone # 732-380-1700		Project Manager		Date		Time		Sampled by		Matrix														# of bottles		IHD		NiOH		HNO3		H2SO4		NONE		DI Water		MEOH		ENCORE					
Sampler(s) Name(s) <i>Bayan Tashy</i>		Phone #		MEQ/HDl Vial #		Collection		Date		Time														Sampled by		Matrix		# of bottles		IHD		NiOH		HNO3		H2SO4		NONE		DI Water		MEOH		ENCORE	
Field ID / Point of Collection		MEQ/HDl Vial #		Date		Time		Sampled by		Matrix														# of bottles		IHD		NiOH		HNO3		H2SO4		NONE		DI Water		MEOH		ENCORE					
CG-FIELD BLANK				3/11/17		1030		151		DFB														1						1															
1 CG-POE						0600				DW														1						1															
2 CG-POE FLUSH						0600				DW														1						1															
3 CG-S-01						0633				DW														1						1															
4 CG-S-01 FLUSH						0633				DW		1						1																											
5 CG-WF-02						0610				DW		1						1																											
6 CG-WF-02 FLUSH						0610				DW		1						1																											
7 CG-S-03						0642				DW		1						1																											
8 CG-S-03 FLUSH						0642				DW		1						1																											
9 CG-S-04						0637				DW		1						1																											
10 CG-S-04 FLUSH						0657				DW		1						1																											
11 CG-WF-05						0657				DW		1						1																											
Turnaround Time (Business days)		Approved By (Accutest PM): / Date:		Data Deliverable Information										Comments / Special Instructions																															
<input type="checkbox"/> Std. 10 Business Days <input checked="" type="checkbox"/> 5 Day RUSH <input type="checkbox"/> 3 Day RUSH <input type="checkbox"/> 2 Day RUSH <input type="checkbox"/> 1 Day RUSH <input type="checkbox"/> other				<input type="checkbox"/> Commercial "A" (Level 1) <input type="checkbox"/> Commercial "B" (Level 2) <input type="checkbox"/> FULLT1 (Level 3+4) <input checked="" type="checkbox"/> NJ Reduced <input type="checkbox"/> Commercial "C" <input type="checkbox"/> NJ Data of Known Quality Protocol Reporting										<input type="checkbox"/> NYASP Category A <input type="checkbox"/> NYASP Category B <input type="checkbox"/> State Forms <input type="checkbox"/> EDD Format <input type="checkbox"/> Other										LOG IN QACHECK & PMCHECK Program code: PAKIDWFB FLUSH SAMPLES ON HOLD!																					
Emergency & Rush T/A data available VIA Lablink		3/13/17 1030		Sample Custody must be documented below each time samples change possession, including courier delivery.																																									
Relinquished by: <i>Bayan Tashy</i>		Date Time: 3/11/17 1800		Received By: <i>[Signature]</i>		Date Time: 3-13-17 1332		Received By: <i>[Signature]</i>		Relinquished By: <i>[Signature]</i>		Date Time: 3-13-17 1332		Received By: <i>[Signature]</i>		Relinquished By: <i>[Signature]</i>		Date Time: 3-13-17 1332		Received By: <i>[Signature]</i>		Relinquished By: <i>[Signature]</i>		Date Time: 3-13-17 1332		Received By: <i>[Signature]</i>		Relinquished By: <i>[Signature]</i>		Date Time: 3-13-17 1332		Received By: <i>[Signature]</i>													
3				3				3				3				3				3				3				3																	
5				5				5				5				5				5				5				5																	
Custody Seal #		Intact		Not Intact		Preserved where applicable										On Ice										Cooler Temp. 03.6																			

JC38837: Chain of Custody



ACCUTEST

CHAIN OF CUSTODY

2235 Route 130, Dayton, NJ 08810
TEL: 732-329-0200 FAX: 732-329-3499/3480
www.accutest.com

FED-EX Tracking #
Bottle Order Control #
Accutest Quote #
Accutest Job # JC38837

Client / Reporting Information
Project Information
Requested Analysis (see TEST CODE sheet)
Matrix Codes
Collection table with columns: Accutest Sample #, Field ID / Point of Collection, MECH/DI Vial #, Date, Time, Sampled by, Matrix, # of bottles, PCB, NiOH, HNO3, H2SO4, HNO2, NONE, D/Water, MEQH, ENCORE, PBMS, TURBIDIMET, LAB USE ONLY.
Turnaround Time (Business days)
Data Deliverable Information
Comments / Special Instructions
LOG IN QACHECK & PMCHECK
Program code: PAK1DWPB
FLUSH SAMPLES ON HOLD
Relinquished by / Received By table with dates and signatures.

JC38837: Chain of Custody



ACCUTEST

CHAIN OF CUSTODY

2235 Route 130, Dayton, NJ 08810
TEL: 732-329-0200 FAX: 732-329-3499/3480
www.accutest.com

FED-EX Tracking #
Bottle Order Control #
Accutest Quote #
Accutest Job # JC38837

Client / Reporting Information
Project Information
Requested Analysis (see TEST CODE sheet)
Matrix Codes

Table with columns: Accutest Sample #, Field ID / Point of Collection, MEQHD1 Vial #, Date, Time, Sampled by, Matrix, # of bottles, and various chemical analysis codes (PC, NiOH, HNO3, H2SO4, HNO2, HNO, DI Water, MEQH, ENCORE). Rows 24-35 show sample details for CG-S-11 through CG-S-17.

Turnaround Time (Business days)
Approved By (Accutest PM): i Date:
Data Deliverable Information
Comments / Special Instructions
LOG IN QACHECK & PMCHECK
Program code: PAK1DWFB
FLUSH SAMPLES ON HOLD!

Relinquished by: Date Time: Received By: Date Time:
Relinquished by: Date Time: Received By: Date Time:
Relinquished by: Date Time: Received By: Date Time:
Custody Seal # Intact Not Intact Preserved where applicable On Ice Cooler Temp.

JC38837: Chain of Custody

Page 3 of 10



ACCUTEST

CHAIN OF CUSTODY

2235 Route 130, Dayton, NJ 08810
TEL: 732-329-0200 FAX: 732-329-3499/3480
www.accutest.com

FED-EX Tracking #
Bottle Order Control #
Accutest Quote #
Accutest Job # JC38837

Client / Reporting Information
Project Information
Requested Analysis (see TEST CODE sheet)
Matrix Codes
LAB USE ONLY
Turnaround Time (Business days)
Data Deliverable Information
Comments / Special Instructions
LOG IN QACHECK & PMCHECK
Program code: PAR1DWPB
FLUSH SAMPLES ON HOLD!
Relinquished by Sampler:
Date Time:
Received By:
Custody Seal #
Intact
Not intact
Preserved where applicable
On Ice
Cooler Temp.

JC38837: Chain of Custody



ACCUTEST

CHAIN OF CUSTODY

2255 Route 130, Dayton, NJ 08810
TEL: 732-329-0200 FAX: 732-329-3499/3480
www.accutest.com

FED-EX Tracking #
Bottle Order Control #
Accutest Quote #
Accutest Job # JC38837

Client / Reporting Information
Project Information
Requested Analysis (see TEST CODE sheet)
Matrix Codes
LAB USE ONLY
Turnaround Time (Business days)
Data Deliverable Information
Comments / Special Instructions
LOG IN QACHECK & PMCHECK
Program code: PAR1DWPB
FLUSH SAMPLES ON HOLD!
Relinquished by:
Received By:
Date Time:
Custody Seal #
Intact
Not intact
Preserved where applicable
On Ice
Cooler Temp.

JC38837: Chain of Custody



ACCUTEST

CHAIN OF CUSTODY

2235 Route 130, Dayton, NJ 08810
TEL 732-329-0200 FAX 732-329-1499/3480
www.accutest.com

FED-EX Tracking #
Bottle Order Control #
Accutest Quote #
Accutest Job # 5C38837

Client / Reporting Information
Project Information
Requested Analysis (see TEST CODE sheet)
Matrix Codes
LAB USE ONLY
Turnaround Time (Business days)
Data Deliverable Information
Comments / Special Instructions
LOG IN QACHECK & PMCHECK
Program code: PAK1DWHB
* Added to CoC 3/15/17

JC38837: Chain of Custody

Page 6 of 10



ACCUTEST

CHAIN OF CUSTODY

2235 Route 130, Dayton, NJ 08810
TEL. 732-329-0200 FAX. 732-329-3499/3480
www.accutest.com

FED-EX Tracking #
Bottle Order Control #
Accutest Quote #
Accutest Job # JC38837

Client / Reporting Information
Project Information
Requested Analysis (see TEST CODE sheet)
Matrix Codes
Company Name: Partner Engineering and Science, Inc
Project Name: Goetz Middle School
Street Address: 611 Industrial Way West
City: Eatontown NJ
Project Contact: Matt Genna
Phone #: 732-380-1700
Sample Name(s): Bryan Bohler
Collection Table with columns: Field ID / Point of Collection, MEQ/MDI Vol #, Date, Time, Sampled by, Matrix, # of bottles, HCl, HNO3, H2SO4, NONE, DI Water, MECH, ENCORE.

Turnaround Time (Business days)
Data Deliverable Information
Comments / Special Instructions
LOG IN QACHECK & PMCHECK
Program code: PARTDWPB
Relinquished by: 1, 3, 5
Received by: 1, 3, 5
Date Time: 3/13/17 1300
Date Time: 3/13/17 1330

JC38837: Chain of Custody

SGS Accutest Sample Receipt Summary

Job Number: JC38837

Client: Partner Engineering

Project: Goetz Middle School

Date / Time Received: 3/13/2017 12:30:00 PM

Delivery Method: Accutest Courier

Airbill #s: _____

Cooler Temps (Raw Measured) °C: Cooler 1: (3.4); Cooler 2: (3.6);

Cooler Temps (Corrected) °C: Cooler 1: (4.8); Cooler 2: (5.0);

<u>Cooler Security</u>	<u>Y</u>	<u>or</u>	<u>N</u>		<u>Y</u>	<u>or</u>	<u>N</u>
1. Custody Seals Present:	<input checked="" type="checkbox"/>		<input type="checkbox"/>	3. COC Present:	<input checked="" type="checkbox"/>		<input type="checkbox"/>
2. Custody Seals Intact:	<input checked="" type="checkbox"/>		<input type="checkbox"/>	4. Smp/ Dates/Time OK	<input checked="" type="checkbox"/>		<input type="checkbox"/>

<u>Cooler Temperature</u>	<u>Y</u>	<u>or</u>	<u>N</u>
1. Temp criteria achieved:	<input checked="" type="checkbox"/>		<input type="checkbox"/>
2. Cooler temp verification:	IR Gun		
3. Cooler media:	Ice (Bag)		
4. No. Coolers:	2		

<u>Quality Control Preservation</u>	<u>Y</u>	<u>or</u>	<u>N</u>	<u>N/A</u>
1. Trip Blank present / cooler:	<input type="checkbox"/>		<input checked="" type="checkbox"/>	<input type="checkbox"/>
2. Trip Blank listed on COC:	<input type="checkbox"/>		<input checked="" type="checkbox"/>	<input type="checkbox"/>
3. Samples preserved properly:	<input checked="" type="checkbox"/>		<input type="checkbox"/>	
4. VOCs headspace free:	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>

<u>Sample Integrity - Documentation</u>	<u>Y</u>	<u>or</u>	<u>N</u>
1. Sample labels present on bottles:	<input checked="" type="checkbox"/>		<input type="checkbox"/>
2. Container labeling complete:	<input checked="" type="checkbox"/>		<input type="checkbox"/>
3. Sample container label / COC agree:	<input checked="" type="checkbox"/>		<input type="checkbox"/>

<u>Sample Integrity - Condition</u>	<u>Y</u>	<u>or</u>	<u>N</u>
1. Sample recvd within HT:	<input checked="" type="checkbox"/>		<input type="checkbox"/>
2. All containers accounted for:	<input checked="" type="checkbox"/>		<input type="checkbox"/>
3. Condition of sample:	Intact		

<u>Sample Integrity - Instructions</u>	<u>Y</u>	<u>or</u>	<u>N</u>	<u>N/A</u>
1. Analysis requested is clear:	<input checked="" type="checkbox"/>		<input type="checkbox"/>	
2. Bottles received for unspecified tests	<input type="checkbox"/>		<input checked="" type="checkbox"/>	
3. Sufficient volume recvd for analysis:	<input checked="" type="checkbox"/>		<input type="checkbox"/>	
4. Compositing instructions clear:	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>
5. Filtering instructions clear:	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>

Comments 1) Did not receive sample "CG-Field Blank"
 2) Did not receive samples "CG-S-22", "CG-S-22 Flush", "CG-WF-35". Samples do not have a collection time noted on COC. Please verify if samples were collected.

SM089-02
 Rev. Date 12/1/16

JC38837: Chain of Custody

Page 8 of 10

Responded to by: Kelly

Response Date: 3/13/17

Response:

"CG-S-22" - This sample was not taken as the outlet was out of service the day of sampling
"CG-S-22 Flush" - This sample was not taken as the outlet was out of service the day of sampling
"CG-WF-35" - This sample was not taken as the ou

JC38837: Chain of Custody

Page 9 of 10

Job Change Order: JC38837

Requested Date: 3/17/2017 **Received Date:** 3/13/2017
Account Name: Partner Engineering & Science **Due Date:** 3/20/2017
Project Description: Goetz Middle School, 835 Patterson Road, Jackson **Deliverable:** REDT2
CSR: kellyp **TAT (Days):** 7

=====
Sample #: JC38837-18, -24, -38, -42, -52 **Change:**
Please remove from hold and run for TURBDWMET, METDIG, and PBMS
Dept:
TAT: 7

=====
Sample #: JC38837-54, -58, -60, -62 **Change:**
Please remove from hold and run for TURBDWMET, METDIG, and PBMS
Dept:
TAT: 7

Above Changes Per: Matt Genna **Date/Time:** 3/17/2017 11:52:27 AM

To Client: This Change Order is confirmation of the revisions, previously discussed with the SGS Accutest Client Service Representative.