

## Sample Summary

**Partner Engineering & Science**

**Job No: JC39207**

**Memorial High School, 101 Don Connor Boulevard, Jackson, NJ**

Sample Number	Collected		Received	Matrix		Client Sample ID
	Date	Time By		Code	Type	
JC39207-1	03/19/17	05:15 EM	03/20/17	DW	Drinking Water FB	JM-FIELD BLANK
JC39207-2	03/19/17	07:28 EM	03/20/17	DW	Drinking Water	JM-POE
JC39207-3	03/19/17	07:29 EM	03/20/17	DW	Drinking Water	JM-POE FLUSH
JC39207-4	03/19/17	07:31 EM	03/20/17	DW	Drinking Water	JM-WF-01
JC39207-6	03/19/17	07:33 EM	03/20/17	DW	Drinking Water	JM-WF-02
JC39207-8	03/19/17	07:26 EM	03/20/17	DW	Drinking Water	JM-WF-03
JC39207-10	03/19/17	07:37 EM	03/20/17	DW	Drinking Water	JM-WF-05
JC39207-12	03/19/17	07:39 EM	03/20/17	DW	Drinking Water	JM-WF-06
JC39207-14	03/19/17	07:41 EM	03/20/17	DW	Drinking Water	JM-WF-07
JC39207-16	03/19/17	07:45 EM	03/20/17	DW	Drinking Water	JM-WF-08
JC39207-18	03/19/17	07:47 EM	03/20/17	DW	Drinking Water	JM-WF-09
JC39207-20	03/19/17	07:52 EE	03/20/17	DW	Drinking Water	JM-WF-11
JC39207-22	03/19/17	07:56 EM	03/20/17	DW	Drinking Water	JM-WF-12

## Sample Summary (continued)

Partner Engineering &amp; Science

Job No: JC39207

Memorial High School, 101 Don Connor Boulevard, Jackson, NJ

Sample Number	Collected		Received	Matrix		Client Sample ID
	Date	Time By		Code	Type	
JC39207-24	03/19/17	08:15 EM	03/20/17	DW	Drinking Water	JM-S-13
JC39207-26	03/19/17	08:17 EM	03/20/17	DW	Drinking Water	JM-S-14
JC39207-28	03/19/17	07:58 EM	03/20/17	DW	Drinking Water	JM-WF-15
JC39207-30	03/19/17	08:24 EM	03/20/17	DW	Drinking Water	JM-S-16
JC39207-32	03/19/17	08:24 EM	03/20/17	DW	Drinking Water	JM-S-17
JC39207-34	03/19/17	08:26 EM	03/20/17	DW	Drinking Water	JM-S-18
JC39207-36	03/19/17	08:26 EM	03/20/17	DW	Drinking Water	JM-S-19
JC39207-38	03/19/17	08:30 EM	03/20/17	DW	Drinking Water	JM-WF-20
JC39207-39	03/19/17	08:31 EM	03/20/17	DW	Drinking Water	JM-WF-20 FLUSH
JC39207-40	03/19/17	08:37 EM	03/20/17	DW	Drinking Water	JM-S-21
JC39207-42	03/19/17	08:40 EM	03/20/17	DW	Drinking Water	JM-WF-22
JC39207-44	03/19/17	08:42 EM	03/20/17	DW	Drinking Water	JM-WF-23
JC39207-46	03/19/17	08:44 KF	03/20/17	DW	Drinking Water	JM-WF-24

## Sample Summary (continued)

Partner Engineering & Science

Job No: JC39207

Memorial High School, 101 Don Connor Boulevard, Jackson, NJ

Sample Number	Collected		Received	Matrix		Client Sample ID
	Date	Time By		Code	Type	
JC39207-48	03/19/17	08:47 KF	03/20/17	DW	Drinking Water	JM-WF-25
JC39207-50	03/19/17	08:50 KF	03/20/17	DW	Drinking Water	JM-WF-26
JC39207-52	03/19/17	08:52 KF	03/20/17	DW	Drinking Water	JM-WF-27
JC39207-54	03/19/17	08:57 KF	03/20/17	DW	Drinking Water	JM-WF-28
JC39207-56	03/19/17	08:59 KF	03/20/17	DW	Drinking Water	JM-WF-29
JC39207-58	03/19/17	08:39 EM	03/20/17	DW	Drinking Water	JM-WF-30
JC39207-60	03/19/17	08:40 EM	03/20/17	DW	Drinking Water	JM-WF-31
JC39207-62	03/19/17	08:42 EM	03/20/17	DW	Drinking Water	JM-WF-32
JC39207-64	03/19/17	08:43 EM	03/20/17	DW	Drinking Water	JM-WF-33
JC39207-66	03/19/17	08:45 EM	03/20/17	DW	Drinking Water	JM-WF-34
JC39207-68	03/19/17	08:46 EM	03/20/17	DW	Drinking Water	JM-WF-35
JC39207-70	03/19/17	08:48 EM	03/20/17	DW	Drinking Water	JM-WF-36
JC39207-72	03/19/17	08:51 EM	03/20/17	DW	Drinking Water	JM-WF-37

## Sample Summary (continued)

Partner Engineering & Science

Job No: JC39207

Memorial High School, 101 Don Connor Boulevard, Jackson, NJ

Sample Number	Collected		Received	Matrix		Client Sample ID
	Date	Time By		Code	Type	
JC39207-74	03/19/17	08:54 EM	03/20/17	DW	Drinking Water	JM-WF-38
JC39207-76	03/19/17	08:57 EM	03/20/17	DW	Drinking Water	JM-WF-40
JC39207-78	03/19/17	09:00 EM	03/20/17	DW	Drinking Water	JM-WF-41
JC39207-80	03/19/17	09:02 EM	03/20/17	DW	Drinking Water	JM-WF-42
JC39207-82	03/19/17	07:08 EM	03/20/17	DW	Drinking Water	JM-WF-43
JC39207-84	03/19/17	07:05 EM	03/20/17	DW	Drinking Water	JM-WF-44
JC39207-86	03/19/17	06:40 EM	03/20/17	DW	Drinking Water	JM-WF-46
JC39207-88	03/19/17	06:37 EM	03/20/17	DW	Drinking Water	JM-S-47
JC39207-90	03/19/17	06:34 EM	03/20/17	DW	Drinking Water	JM-S-48
JC39207-92	03/19/17	06:49 EM	03/20/17	DW	Drinking Water	JM-WF-49
JC39207-94	03/19/17	06:52 EM	03/20/17	DW	Drinking Water	JM-WF-50
JC39207-96	03/19/17	06:49 EM	03/20/17	DW	Drinking Water	JM-WF-51
JC39207-98	03/19/17	06:51 EM	03/20/17	DW	Drinking Water	JM-WF-52

**Sample Summary**  
(continued)

**Partner Engineering & Science**

**Job No: JC39207**

**Memorial High School, 101 Don Connor Boulevard, Jackson, NJ**

Sample Number	Collected		Received	Matrix		Client Sample ID
	Date	Time By		Code	Type	
JC39207-100	03/19/17	06:57 EM	03/20/17	DW	Drinking Water	JM-WF-54
JC39207-102	03/19/17	06:21 EM	03/20/17	DW	Drinking Water	JM-WF-55
JC39207-104	03/19/17	06:07 EM	03/20/17	DW	Drinking Water	JM-WF-56
JC39207-106	03/19/17	05:59 EM	03/20/17	DW	Drinking Water	JM-S-57
JC39207-108	03/19/17	06:02 EM	03/20/17	DW	Drinking Water	JM-IM-58
JC39207-110	03/19/17	06:00 EM	03/20/17	DW	Drinking Water	JM-S-59
JC39207-112	03/19/17	05:48 EM	03/20/17	DW	Drinking Water	JM-IM-60
JC39207-113	03/19/17	05:49 EM	03/20/17	DW	Drinking Water	JM-IM-60 FLUSH
JC39207-114	03/19/17	05:47 EM	03/20/17	DW	Drinking Water	JM-S-61
JC39207-116	03/19/17	05:52 EM	03/20/17	DW	Drinking Water	JM-WF-62
JC39207-118	03/19/17	05:54 EM	03/20/17	DW	Drinking Water	JM-WF-63
JC39207-120	03/19/17	05:19 EM	03/20/17	DW	Drinking Water	JM-WF-64
JC39207-122	03/19/17	05:22 EM	03/20/17	DW	Drinking Water	JM-S-65

### Sample Summary (continued)

Partner Engineering & Science

Job No: JC39207

Memorial High School, 101 Don Connor Boulevard, Jackson, NJ

Sample Number	Collected		Received	Matrix		Client Sample ID
	Date	Time By		Code	Type	
JC39207-123	03/19/17	05:23 EM	03/20/17	DW	Drinking Water	JM-S-65 FLUSH
JC39207-124	03/19/17	06:10 EM	03/20/17	DW	Drinking Water	JM-WF-66
JC39207-126	03/19/17	06:15 EM	03/20/17	DW	Drinking Water	JM-WF-67
JC39207-128	03/19/17	06:17 EM	03/20/17	DW	Drinking Water	JM-S-68
JC39207-130	03/19/17	07:12 EM	03/20/17	DW	Drinking Water	JM-S-69
JC39207-132	03/19/17	07:12 EM	03/20/17	DW	Drinking Water	JM-S-70
JC39207-134	03/19/17	07:13 EM	03/20/17	DW	Drinking Water	JM-S-71
JC39207-136	03/19/17	07:20 EM	03/20/17	DW	Drinking Water	JM-S-72
JC39207-138	03/19/17	07:20 EM	03/20/17	DW	Drinking Water	JM-S-73
JC39207-140	03/19/17	07:21 EM	03/20/17	DW	Drinking Water	JM-S-74
JC39207-141	03/19/17	07:22 EM	03/20/17	DW	Drinking Water	JM-S-74 FLUSH
JC39207-142	03/19/17	05:29 EM	03/20/17	DW	Drinking Water	JM-WF-75
JC39207-144	03/19/17	05:31 EM	03/20/17	DW	Drinking Water	JM-WF-76

**Sample Summary**  
(continued)

**Partner Engineering & Science**

**Job No: JC39207**

**Memorial High School, 101 Don Connor Boulevard, Jackson, NJ**

<b>Sample Number</b>	<b>Collected Date</b>	<b>Time By</b>	<b>Received</b>	<b>Matrix Code</b>	<b>Type</b>	<b>Client Sample ID</b>
JC39207-146	03/19/17	08:21 EM	03/20/17	DW	Drinking Water	JM-S-77
JC39207-148	03/19/17	05:34 EM	03/20/17	DW	Drinking Water	JM-S-78
JC39207-150	03/19/17	05:38 EM	03/20/17	DW	Drinking Water	JM-S-79
JC39207-152	03/19/17	08:23 EM	03/20/17	DW	Drinking Water	JM-IM-80

## Report of Analysis

<b>Client Sample ID:</b> JM-FIELD BLANK	
<b>Lab Sample ID:</b> JC39207-1	<b>Date Sampled:</b> 03/19/17
<b>Matrix:</b> DW - Drinking Water FB	<b>Date Received:</b> 03/20/17
	<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ	

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99356

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)



## Report of Analysis

<b>Client Sample ID:</b> JM-POE		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-2		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.0247	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99356

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-POE FLUSH		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-3		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00142	0.015	0.00050	mg/l	1	03/24/17	03/24/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41638

(2) Prep QC Batch: MP99463

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-01		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-4		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00545	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99356

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-02		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-6		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99356

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-03		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-8		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.000930	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99356

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-05		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-10		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99356

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-06		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-12		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99356

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-07		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-14		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99356

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)



## Report of Analysis

<b>Client Sample ID:</b> JM-WF-08		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-16		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00592	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99356

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-09		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-18		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00179	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99356

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-11		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-20		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.000509	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99357

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-12		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-22		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99357

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-S-13		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-24		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99357

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-S-14		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-26		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00167	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99357

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-15		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-28		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00201	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99357

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-S-16		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-30		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00169	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99357

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)



## Report of Analysis

<b>Client Sample ID:</b> JM-S-17		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-32		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99357

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-S-18		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-34		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.000811	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99357

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-S-19		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-36		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00100	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99357

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-20		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-38		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.0238	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99357

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-20 FLUSH		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-39		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.0126	0.015	0.00050	mg/l	1	03/24/17	03/24/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41638

(2) Prep QC Batch: MP99463

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-S-21		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-40		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99358

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-22		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-42		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00947	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99358

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-23		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-44		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.000523	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99358

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)



## Report of Analysis

<b>Client Sample ID:</b> JM-WF-24		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-46		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99358

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-25		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-48		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99358

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-26		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-50		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.000513	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99358

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-27		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-52		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.000651	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99358

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-28		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-54		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99358

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-29		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-56		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00154	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99358

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-30		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-58		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.000584	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99358

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-31		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-60		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00264	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99359

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)



## Report of Analysis

<b>Client Sample ID:</b> JM-WF-32		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-62		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00209	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99359

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-33		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-64		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00337	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99359

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-34		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-66		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00155	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99359

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-35		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-68		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00133	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99359

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-36		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-70		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99359

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-37		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-72		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99359

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-38		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-74		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99359

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-40		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-76		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99359

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)



## Report of Analysis

<b>Client Sample ID:</b> JM-WF-41		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-78		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00150	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99359

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-42		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-80		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99360

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-43		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-82		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00162	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99360

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-44		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-84		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99360

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-46		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-86		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00287	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99360

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-S-47		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-88		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00139	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99360

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-S-48		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-90		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00118	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99360

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-49		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-92		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00187	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99360

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)



## Report of Analysis

<b>Client Sample ID:</b> JM-WF-50		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-94		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00146	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99360

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-51		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-96		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00190	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99360

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-52		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-98		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00232	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99360

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-54		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-100		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00599	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99361

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-55		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-102		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00133	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99361

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-56		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-104		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99361

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-S-57		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-106		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99361

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-IM-58		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-108		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00943	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99361

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)



## Report of Analysis

<b>Client Sample ID:</b> JM-S-59		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-110		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99361

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-IM-60		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-112		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.0260	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99361

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-IM-60 FLUSH		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-113		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00150	0.015	0.00050	mg/l	1	03/24/17	03/24/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41638

(2) Prep QC Batch: MP99463

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-S-61		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-114		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.000861	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99361

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-62		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-116		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99361

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-63		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-118		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99361

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-64		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-120		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.000819	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99362

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-S-65		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-122		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.0392	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99362

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)



## Report of Analysis

<b>Client Sample ID:</b> JM-S-65 FLUSH		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-123		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00230	0.015	0.00050	mg/l	1	03/24/17	03/24/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41638

(2) Prep QC Batch: MP99463

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-66		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-124		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99362

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-67		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-126		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00285	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99362

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-S-68		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-128		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00176	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99362

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-S-69		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-130		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00115	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99362

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-S-70		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-132		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00105	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99362

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-S-71		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-134		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00303	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99362

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-S-72		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-136		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00244	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99362

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)



## Report of Analysis

<b>Client Sample ID:</b> JM-S-73		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-138		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00320	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99362

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-S-74		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-140		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.0206	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99363

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-S-74 FLUSH		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-141		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00123	0.015	0.00050	mg/l	1	03/24/17	03/24/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41638

(2) Prep QC Batch: MP99463

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-75		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-142		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00316	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99363

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-WF-76		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-144		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00153	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99363

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-S-77		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-146		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00490	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99363

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-S-78		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-148		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99363

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JM-S-79		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-150		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.000779	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99363

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)



## Report of Analysis

<b>Client Sample ID:</b> JM-IM-80		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39207-152		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Memorial High School, 101 Don Connor Boulevard, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/21/17	03/21/17 MS	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41620

(2) Prep QC Batch: MP99363

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)



ACCUTEST

D10  
FB

CHAIN OF CUSTODY

2235 Route 130, Dayton, NJ 08810  
TEL: 732-329-0200 FAX: 732-329-3499/3480  
www.accutest.com

FED-EX Tracking #	Bottle Order Control #
Accutest Quote #	Accutest Job # <b>JC39207</b>

Client / Reporting Information		Project Information										Requested Analysis ( see TEST CODE sheet)											Matrix Codes												
Company Name <b>Partner Engineering and Science, Inc</b>		Project Name <b>Memorial High School</b>										PBM5, TURBIDIMET											DW - Drinking Water GW - Ground Water WW - Water SW - Surface Water SO - Soil SL - Sludge SED - Sediment OI - Oil LIQ - Other Liquid AIR - Air SOL - Other Solid WP - Wipe FB - Field Blank EB - Equipment Blank RB - Rinse Blank TB - Trip Blank												
Street Address <b>611 Industrial Way West</b>		Street <b>101 Don Connor Blvd</b>																																	
City <b>Eatontown NJ</b>		City <b>Jackson NJ</b>					State <b>NJ</b>																		Billing Information ( If different from Report to )										
Project Contact <b>Matt Genna</b>		Project #					Street Address																		Company Name										
Phone # <b>732-380-1700</b>		Client Purchase Order #					City																		State					Zip					
Sampler(s) Name(s) <b>Elaine Moss</b>		Phone #		Project Manager		Attention:		Collection											LAB USE ONLY																
Accutest Sample #	Field ID / Point of Collection	MEOH/DI Vial #	Date	Time	Sampled by	Matrix	# of bottles	Number of preserved Bottles											LAB USE ONLY																
								HCl	NaOH	HN03	H2SO4	NACNE	D1 Washer	MEOH	ENCORE																				
1	JM-FIELD BLANK		3/19/17	5:16	EM	DFB	1	1																											
2	JM-POE		(728) 3/19/17	7:50		DW	1	1															A36												
3	JM-POE FLUSH			7:24		DW	1	1																											
4	JM-WF-01			7:3		DW	1	1																											
5	JM-WF-01 FLUSH			7:32		DW	1	1																											
6	JM-WF-02			7:33		DW	1	1																											
7	JM-WF-02 FLUSH			7:37		DW	1	1																											
8	JM-WF-03			9:26		DW	1	1																											
9	JM-WF-03 FLUSH			7:27		DW	1	1																											
-	JM-WF-04					DW																	INITIAL ASSESSMENT 2A												
-	JM-WF-04 FLUSH					DW																	LABEL VERIFICATION												
10	JM-WF-05			7:37		DW	1	1																											
Turnaround Time ( Business days)		Data Deliverable Information										Comments / Special Instructions																							
<input type="checkbox"/> Std. 10 Business Days <input checked="" type="checkbox"/> 5 Day RUSH <input type="checkbox"/> 3 Day RUSH <input type="checkbox"/> 2 Day RUSH <input type="checkbox"/> 1 Day RUSH <input type="checkbox"/> other _____ Emergency & Rush TIA data available VIA Lablink		Approved By (Accutest PM): / Date:		<input type="checkbox"/> Commercial "A" ( Level 1 ) <input type="checkbox"/> Commercial "B" ( Level 2 ) <input type="checkbox"/> FULLT1 ( Level 3+4 ) <input checked="" type="checkbox"/> NJ Reduced <input type="checkbox"/> Commercial "C" <input type="checkbox"/> NJ Data of Known Quality Protocol Reporting <small>Commercial "A" = Results Only, Commercial "B" = Results + QC Summary          NJ Reduced = Results + QC Summary + Partial Raw data</small>										<input type="checkbox"/> NYASP Category A <input type="checkbox"/> NYASP Category B <input type="checkbox"/> State Forms <input type="checkbox"/> EDD Format <input type="checkbox"/> Other _____		LOG IN QACHECK & PMCHECK Program code: PAK1LWFPB FLUSH SAMPLES ON HOLD! <b>Analyze flush if initial is over 6ppb</b>																			
Relinquished by Sampler: <b>e Moss</b>		Date Time: <b>3/19/17 10:50</b>	Sample Custody must be documented below each time samples change possession, including courier delivery.										Date Time: <b>12:40</b>	Received By:																					
Relinquished by Sampler:		Date Time:	Received By: <b>Heek Pankle</b>										Date Time: <b>3:20 17</b>	Received By: <b>J</b>																					
Relinquished by:		Date Time:	Received By: <b>Heek Pankle</b>										Date Time:	Received By: <b>24CIP 31CIP 34CIP 38CIP</b>																					
Custody Seal # <b>602</b>		<input checked="" type="checkbox"/> Intact <input type="checkbox"/> Not Intact										Preserved where applicable		On Ice / Cooler Temp.																					

JC39207: Chain of Custody



ACCUTEST

CHAIN OF CUSTODY

2235 Route 130, Dayton, NJ 08810
TEL 732-329-0200 FAX: 732-329-3499/3480
www.accutest.com

FED-EX Tracking #
Bottle Order Control #
Accutest Quote #
Accutest Job # JC39207

Table with columns: Client / Reporting Information, Project Information, Requested Analysis (see TEST CODE sheet), Matrix Codes. Includes fields for Company Name (Partner Engineering and Science, Inc), Project Name (Memorial High School), Address (611 Industrial Way West, Eatontown NJ), and a detailed collection log with sample IDs (JM-WF-05 to JM-WF-11), dates (3/16/17), times (7:38 AM), and matrix types (DW).

Turnaround Time (Business days)
Data Deliverable Information
Comments / Special Instructions
LOG IN QACHECK & PMCHECK
Program code: PAR1DWPB
FLUSH SAMPLES ON HOLD!

Table for Chain of Custody with columns: Relinquished by, Date Time, Received By, Date Time, Relinquished By, Date Time. Includes signatures and dates for samples 1, 3, and 5.

JC39207: Chain of Custody



ACCUTEST

CHAIN OF CUSTODY

2235 Route 130, Dayton, NJ 08810
TEL: 732-329-0200 FAX: 732-329-3499/3480
www.accutest.com

FED-EX Tracking #
Bottle Order Control #
Accutest Quote #
Accutest Job # JC39207

Table with columns: Client / Reporting Information, Project Information, Requested Analysis (see TEST CODE sheet), Matrix Codes. Includes sample details for JM-WF-11 through JM-S-17.

Turnaround Time (Business days)
Data Deliverable Information
Comments / Special Instructions
LOG IN QACHECK & PMCHECK
Program code: PAK1DWPB
FLUSH SAMPLES ON HOLD!

Table for Chain of Custody with columns: Relinquished by Sampler, Date/Time, Received By, Date/Time, Relinquished By, Date/Time. Includes handwritten signatures and dates.



ACCUTEST

CHAIN OF CUSTODY

2235 Route 130, Dayton, NJ 08810
TEL: 732-329-0200 FAX: 732-329-3499/3480
www.accutest.com

FED-EX Tracking #
Bottle Order Control #
Accutest Quote #
Accutest Job # JC39207

Table with columns: Client / Reporting Information, Project Information, Requested Analysis (see TEST CODE sheet), Matrix Codes. Includes fields for Company Name (Partner Engineering and Science, Inc), Project Name (Memorial High School), Address (611 Industrial Way West, Eatontown, NJ), and a detailed collection log with sample IDs (JM-S-17 to JM-WF-23), dates, times, and analysis results.

Turnaround Time (Business days)
Data Deliverable Information
Comments / Special Instructions
LOG IN QACHECK & PMCHECK
Program code: PAR1DWPB
FLUSH SAMPLES ON HOLD!

Table for Chain of Custody with columns: Relinquished by Sampler, Date Time, Received By, Date Time, Relinquished By, Date Time, Received By, Date Time. Includes handwritten signatures and dates for samples 1 through 5.



ACCUTEST

CHAIN OF CUSTODY

2235 Route 130, Dayton, NJ 08810
TEL: 732-329-0200 FAX: 732-329-3499/3480
www.accutest.com

FED-EX Tracking #
Bottle Order Control #
Accutest Quote #
Accutest Job # 5C39207

Table with columns: Client / Reporting Information, Project Information, Requested Analysis (see TEST CODE sheet), Matrix Codes. Includes sample details for JM-WF-23 through JM-WF-29.

Turnaround Time (Business days)
Data Deliverable Information
Comments / Special Instructions
LOG IN QACHECK & PMCHECK
Program code: PAK1DWPB
FLUSH SAMPLES ON HOLD!

Table for chain of custody with columns: Relinquished by, Date Time, Received By, Date Time, Relinquished By, Date Time, Received By, Date Time. Includes handwritten signatures and dates.

JC39207: Chain of Custody



ACCUTEST

CHAIN OF CUSTODY

2235 Route 130, Dayton, NJ 08810
TEL: 732-329-0200 FAX: 732-329-3499/3480
www.accutest.com

FED-EX Tracking #
Bottle Order Control #
Accutest Quote #
Accutest Job # JC39207

Client / Reporting Information: Partner Engineering and Science, Inc. Project Information: Memorial High School. Requested Analysis (see TEST CODE sheet). Matrix Codes: DW - Drinking Water, GW - Ground Water, etc. Collection table with columns for Date, Time, Matrix, # of bottles, and various chemical tests. Turnaround Time: 5 Day RUSH. Data Deliverable Information: Commercial "A" (Level 1), Commercial "B" (Level 2), NJ Reduced, Commercial "C", NJ Data of Known Quality Protocol Reporting. Chain of Custody table with 5 entries showing relinquished and received by dates and times.

JC39207: Chain of Custody



ACCUTEST

CHAIN OF CUSTODY

2235 Route 130, Dayton, NJ 08810
TEL: 732-329-0200 FAX: 732-329-3499/3480
www.accutest.com

FED-EX Tracking #
Bottle Order Control #
Accutest Quote #
Accutest Job # JC39207

Client / Reporting Information
Partner Engineering and Science, Inc
611 Industrial Way West
Eatontown NJ
Matt Genna
732-380-1700
Elie Moss
Project Information
Memorial High School
101 Don Connor Blvd
Jackson NJ
Billing Information (if different from Report to)
Company Name
Street Address
City State
Project #
Street Address
Client Purchase Order #
City State Zip
Project Manager
Attention:

Table with columns: Accutest Sample #, Field ID / Point of Collection, MEOWDI Vial #, Date, Time, Sampled by, Matrix, # of bottles, HCl, NaOH, HNO3, H2SO4, HNO2, DI Water, MEOH, ENDORE, Matrix Codes, LAB USE ONLY. Rows include samples 69-78.

Turnaround Time (Business days)
Data Deliverable Information
Comments / Special Instructions
LOG IN QACHECK & PMCHECK
Program code: PAR1DWPB
FLUSH SAMPLES ON HOLD!

Emergency & Rush T/A data available VIA Lablink
Sample Custody must be documented below each time samples change possession, including courier delivery.
Relinquished by: E Moss
Date Time: 3/19/17 10:50
Received By: [Signature]
Date Time: 3:20:17
Relinquished by: [Signature]
Date Time: 3
Received By: [Signature]
Date Time: 4
Received By: [Signature]





ACCUTEST

CHAIN OF CUSTODY

2235 Route 130, Dayton, NJ 08810
TEL: 732-329-0200 FAX: 732-329-3499/3480
www.accutest.com

FED-EX Tracking #
Bottle Order Control #
Accutest Quote #
Accutest Job # JC39207

Client / Reporting Information
Project Information
Requested Analysis (see TEST CODE sheet)
Matrix Codes

Table with columns: Accutest Sample #, Field ID / Point of Collection, MEQ/HD/Vial #, Date, Time, Matrix, # of bottles, HCl, NaOH, HNO3, H2SO4, NONE, DI Water, MESH, ENCORE, LAB USE ONLY. Includes handwritten entries for samples 79-88.

Turnaround Time (Business days)
Data Deliverable Information
Comments / Special Instructions
LOG IN QACHECK & PMCHECK
Program code: PAR1DWPB
FLUSH SAMPLES ON HOLD!

Sample Custody must be documented below each time samples change possession, including courier delivery.
Relinquished by: 1 E. Mass Date Time: 3/19/17 10:50
Received By: 1 [Signature]
Relinquished by: 2 [Signature] Date Time: 12:40
Received By: 2 [Signature]
Relinquished by: 3 Date Time: 3:20:17
Received By: 3
Relinquished by: 4
Received By: 4
Relinquished by: 5
Received By: 5
Custody Seal # 602
Intact Not Intact
Preserved where applicable
On Ice Cooler Temp.

JC39207: Chain of Custody



ACCUTEST

CHAIN OF CUSTODY

2235 Route 130, Dayton, NJ 08810
TEL: 732-329-0200 FAX: 732-329-3499/3480
www.accutest.com

FED-EX Tracking #
Bottle Order Control #
Accutest Quote #
Accutest Job # JC39207

Client / Reporting Information
Partner Engineering and Science, Inc
611 Industrial Way West
Eatontown NJ
Matt Genna
732-380-1700
Elaine Moss

Table with columns: Accutest Sample #, Field ID / Point of Collection, MECH/DI Vial #, Date, Time, Matrix, # of bottles, HCl, HNO3, H2SO4, NONE, DI Water, MECH, ENCORE, Matrix Codes, LAB USE ONLY. Includes handwritten entries for samples 89-99.

Turnaround Time (Business days)
Data Deliverable Information
Comments / Special Instructions
LOG IN QACHECK & PMCHECK
Program code: PAK1DWPB
FLUSH SAMPLES ON HOLD!

Sample Custody must be documented below each time samples change possession, including courier delivery.
Relinquished by: [Signature] Date Time: 3/19/17
Received By: [Signature] Date Time: 3/20/17

JC39207: Chain of Custody



ACCUTEST

CHAIN OF CUSTODY

2235 Route 130, Dayton, NJ 08810
TEL: 732-329-0200 FAX: 732-329-3499/3480
www.accutest.com

FED-EX Tracking #
Bottle Order Control #
Accutest Quote #
Accutest Job # JC39207

Table with columns: Client / Reporting Information, Project Information, Requested Analysis (see TEST CODE sheet), Matrix Codes. Includes fields for Company Name (Partner Engineering and Science, Inc), Project Name (Memorial High School), and a detailed collection log with sample IDs (JM-WF-54, JM-S-57, JM-IM-58), dates, times, and analysis results.

Turnaround Time (Business days)
Data Deliverable Information
Comments / Special Instructions
LOG IN QACHECK & PMCHECK
Program code: PAK1DWPB
FLUSH SAMPLES ON HOLD!

Table for Chain of Custody with columns: Relinquished by, Date Time, Received By, Date Time. Includes handwritten signatures and dates for steps 1 through 5.



ACCUTEST

CHAIN OF CUSTODY

2235 Route 130, Dayton, NJ 08810
TEL: 732-329-0200 FAX: 732-329-3499/3480
www.accutest.com

FED-EX Tracking #
Accutest Quote #
Accutest Job # JC39207

Client / Reporting Information: Partner Engineering and Science, Inc.
Project Name: Memorial High School
Requested Analysis (see TEST CODE sheet)
Matrix Codes: DW - Drinking Water, GW - Ground Water, etc.
Collection table with columns: Date, Time, Sampled by, Matrix, # of bottles, HCl, NaOH, HPO3, HPO4, NO3, DI Water, MICH, ENCORE.
Turnaround Time (Business days)
Data Deliverable Information
Emergency & Rush T/A data available VIA Lablink
Sample Custody must be documented below each time samples change possession, including courier delivery.
Relinquished by: 1 E. Mena, 3, 5
Received by: 2, 3, 4, 5
Custody Seal # 610
On Ice checked



ACCUTEST

CHAIN OF CUSTODY

2235 Route 130, Dayton, NJ 08810
TEL: 732-329-0200 FAX: 732-329-3499/3480
www.accutest.com

FED-EX Tracking #
Bottle Order Control #
Accutest Quote #
Accutest Job # JC39207

Client / Reporting Information
Project Information
Requested Analysis (see TEST CODE sheet)
Matrix Codes
Company Name: Partner Engineering and Science, Inc
Project Name: Memorial High School
Street Address: 611 Industrial Way West
City: Eatontown NJ
Project Contact: Matt Genna
Phone #: 732-380-1700
Sampler(s) Name(s): Ellie Moss
Project Manager:
Attention:
Collection table with columns: Date, Time, Sampled by, Matrix, # of bottles, HCl, NaOH, HNO3, H2SO4, HNO2, DI Water, MESH, ENCORE. Rows 123-134.

Turnaround Time (Business days)
Data Deliverable Information
Comments / Special Instructions
LOG IN QACHECK & PMCHECK
Program code: PAR1DWPF
FLUSH SAMPLES ON HOLD!

Sample Custody must be documented below each time samples change possession, including courier delivery.
Relinquished by: e moss
Date Time: 3/19/17
Received By: [Signature]
Date Time: 12:40
Received By: [Signature]
Relinquished by: [Signature]
Date Time: 3
Received By: [Signature]
Date Time: 3:20:17
Received By: [Signature]
Relinquished by: [Signature]
Date Time: 5
Received By: [Signature]
Date Time: 4
Custody Seal #: 604
Intact [checked]
Not intact [ ]
Preserved where applicable [ ]
On Ice [checked]
Cooler Temp. [ ]

JC39207: Chain of Custody



ACCUTEST

CHAIN OF CUSTODY

2235 Route 130, Dayton, NJ 08810
TEL: 732-329-0200 FAX: 732-329-3499/3480
www.accutest.com

FED-EX Tracking #
Bottle Order Control #
Accutest Quote #
Accutest Job # JC39207

Table with columns: Client / Reporting Information, Project Information, Requested Analysis (see TEST CODE sheet), Matrix Codes. Includes fields for Company Name (Partner Engineering and Science, Inc), Project Name (Memorial High School), and a detailed collection log with sample numbers (135-144), dates, times, and analysis results.

Turnaround Time (Business days)
Approved By (Accutest PM): / Date:
Commercial "A" (Level 1)
Commercial "B" (Level 2)
FULLT1 (Level 3+4)
NJ Reduced
Commercial "C"
NJ Data of Known Quality Protocol Reporting
Commercial "A" = Results Only, Commercial "B" = Results + QC Summary
NJ Reduced = Results + QC Summary + Partial Raw data
LOG IN QACHECK & PMCHECK
Program code: PAKIDWPPB
FLUSH SAMPLES ON HOLD!

Table for Chain of Custody with columns: Relinquished by Sampler, Date Time, Received By, Date Time, Relinquished By, Date Time, Received By, Date Time. Includes handwritten signatures and dates for samples 1, 2, 3, 4, and 5.



ACCUTEST

CHAIN OF CUSTODY

SGS Accutest - Dayton
2235 Route 130, Dayton, NJ 08810
TEL: 732-329-0200 FAX: 732-329-3499/3480
www.accutest.com

Form containing Client/Reporting Information, Project Information, Collection table with sample IDs (e.g., JM-76 F), dates, times, and analysis results. Includes sections for Turnaround Time, Approved by, and Relinquished/Received by signatures and dates.

SM088-01C Rev. Date: 9/13/16

JC39207: Chain of Custody

Page 14 of 17

## SGS Accutest Sample Receipt Summary

**Job Number:** JC39207

**Client:** Partner Engineering

**Project:** Memorial High School

**Date / Time Received:** 3/20/2017 12:40:00 PM

**Delivery Method:** Accutest Courier

**Airbill #s:** \_\_\_\_\_

**Cooler Temps (Raw Measured) °C:** Cooler 1: (2.4); Cooler 2: (3.1); Cooler 3: (3.4); Cooler 4: (3.3);

**Cooler Temps (Corrected) °C:** Cooler 1: (3.8); Cooler 2: (4.5); Cooler 3: (4.8); Cooler 4: (4.7);

<u>Cooler Security</u>	<u>Y or N</u>			<u>Y or N</u>	
1. Custody Seals Present:	<input checked="" type="checkbox"/>	<input type="checkbox"/>	3. COC Present:	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2. Custody Seals Intact:	<input checked="" type="checkbox"/>	<input type="checkbox"/>	4. Smpl Dates/Time OK	<input checked="" type="checkbox"/>	<input type="checkbox"/>

<u>Cooler Temperature</u>	<u>Y or N</u>	
1. Temp criteria achieved:	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2. Cooler temp verification:	IR Gun	
3. Cooler media:	Ice (Bag)	
4. No. Coolers:	4	

<u>Quality Control Preservation</u>	<u>Y or N</u>		<u>N/A</u>
1. Trip Blank present / cooler:	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2. Trip Blank listed on COC:	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
3. Samples preserved properly:	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
4. VOCs headspace free:	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

<u>Sample Integrity - Documentation</u>	<u>Y or N</u>	
1. Sample labels present on bottles:	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2. Container labeling complete:	<input checked="" type="checkbox"/>	<input type="checkbox"/>
3. Sample container label / COC agree:	<input checked="" type="checkbox"/>	<input type="checkbox"/>

<u>Sample Integrity - Condition</u>	<u>Y or N</u>	
1. Sample recvd within HT:	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2. All containers accounted for:	<input checked="" type="checkbox"/>	<input type="checkbox"/>
3. Condition of sample:	Intact	

<u>Sample Integrity - Instructions</u>	<u>Y or N</u>		<u>N/A</u>
1. Analysis requested is clear:	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
2. Bottles received for unspecified tests	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
3. Sufficient volume recvd for analysis:	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
4. Compositing instructions clear:	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
5. Filtering instructions clear:	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Comments -152 & -153 Rec'd limited volume of approx 75ml's.

SM089-02  
Rev. Date 12/1/16



Responded to by: Kelly

Response Date: 3/20/17

Response:

Please proceed as noted

**JC39207: Chain of Custody**  
**Page 16 of 17**

**Job Change Order: JC39207**

**Requested Date:** 3/23/2017      **Received Date:** 3/20/2017  
**Account Name:** Partner Engineering & Science      **Due Date:** 3/27/2017  
**Project Description:** Memorial High School, 101 Don Connor Boulevard,      **Deliverable:** REDT2  
**CSR:** kellyp      **TAT (Days):** 7

=====  
**Sample #:** JC39207-3, -39, -113, -123, -141      **Change:**

Please remove from hold and run for PBMS and TURBDWMET

**Dept:**

**TAT:** 7

**Above Changes Per:** Matt Genna      **Date/Time:** 3/23/2017 4:37:02 PM

To Client: This Change Order is confirmation of the revisions, previously discussed with the SGS Accutest Client Service Representative.