

### Report of Analysis

<b>Client Sample ID:</b> FIELD BLANK-JL	<b>Date Sampled:</b> 04/05/17
<b>Lab Sample ID:</b> JC40473-9	<b>Date Received:</b> 04/05/17
<b>Matrix:</b> DW - Drinking Water FB	<b>Percent Solids:</b> n/a
<b>Project:</b> Jackson BOE Round 2 Jackson, NJ	

#### Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	04/08/17	04/08/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41752

(2) Prep QC Batch: MP99781

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> JL-IM-42	<b>Date Sampled:</b> 04/05/17
<b>Lab Sample ID:</b> JC40473-10	<b>Date Received:</b> 04/05/17
<b>Matrix:</b> DW - Drinking Water	<b>Percent Solids:</b> n/a
<b>Project:</b> Jackson BOE Round 2 Jackson, NJ	

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00369	0.015		0.00050 mg/l	1	04/08/17	04/08/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41752

(2) Prep QC Batch: MP99781

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

4.10  
4

## Report of Analysis

<b>Client Sample ID:</b> JL-IM-42 FLUSH <b>Lab Sample ID:</b> JC40473-11 <b>Matrix:</b> DW - Drinking Water <b>Project:</b> Jackson BOE Round 2 Jackson, NJ	<b>Date Sampled:</b> 04/05/17 <b>Date Received:</b> 04/05/17 <b>Percent Solids:</b> n/a
--	---

4.11  
4

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	04/08/17	04/08/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41752

(2) Prep QC Batch: MP99782

RL = Reporting Limit  
 MCL = Maximum Contamination Level (NJAC 7:10 11/04)

# Report of Analysis

<b>Client Sample ID:</b> JL-IM-54	<b>Date Sampled:</b> 04/05/17
<b>Lab Sample ID:</b> JC40473-12	<b>Date Received:</b> 04/05/17
<b>Matrix:</b> DW - Drinking Water	<b>Percent Solids:</b> n/a
<b>Project:</b> Jackson BOE Round 2 Jackson, NJ	

4.12  
4

### Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.0131	0.015	0.00050	mg/l	1	04/08/17	04/08/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41752

(2) Prep QC Batch: MP99782

RL = Reporting Limit

MCL = Maximum Contamination Level (NJAC 7:10 11/04)

# Report of Analysis

<b>Client Sample ID:</b> JL-IM-54 FLUSH	<b>Date Sampled:</b> 04/05/17
<b>Lab Sample ID:</b> JC40473-13	<b>Date Received:</b> 04/05/17
<b>Matrix:</b> DW - Drinking Water	<b>Percent Solids:</b> n/a
<b>Project:</b> Jackson BOE Round 2 Jackson, NJ	

## Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00407	0.015	0.00050	mg/l	1	04/08/17	04/08/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41752

(2) Prep QC Batch: MP99782

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)