



DRINKING WATER SAMPLING REPORT

Memorial High School

101 Don Connor Boulevard
Jackson, New Jersey 08527

April 25, 2022
Partner Project No. 21-327918.1



Prepared for

Jackson Township Board of Education

151 Don Connor Boulevard
Jackson, New Jersey 08527

April 25, 2022

Mr. Anthony Bruno
Jackson Township Board of Education
151 Don Connor Boulevard
Jackson, New Jersey 08527

Subject: Drinking Water Sampling Report
 Jackson Township Board of Education
 Memorial High School
 Jackson, New Jersey 08527
 Partner Project 21-327918.1

Dear Mr. Bruno:

Partner Engineering and Science, Inc. (Partner) is pleased to provide the results of the *Drinking Water Sampling* conducted at the abovementioned address (the "subject property"). This sampling event was performed in general conformance with the scope and limitations as detailed in our fee proposal. This inspection included a site reconnaissance as well as sampling and analysis. An assessment was made, conclusions stated, and recommendations outlined, as required.

We appreciate the opportunity to provide environmental services to the Jackson Township Board of Education. If you have any questions concerning this report, or if we can assist you in any other matter, please contact me at (908) 497-8904 or via e-mail at dbracey@partneresi.com.

Sincerely,



Dan Bracey, CSP, CHMM
Senior Project Manager
Industrial Hygiene & Health and Safety Services

TABLE OF CONTENTS

Executive Summary.....	2
1.0 INTRODUCTION	3
1.1 Property Description.....	3
1.2 Purpose and Scope	3
2.0 METHODOLOGY	4
3.0 BACKGROUND	5
4.0 ANALYTICAL RESULTS	6
5.0 CONCLUSION.....	10
6.0 RECOMMENDATIONS	11
7.0 LIMITATIONS	11
8.0 SIGNATURES OF PROFESSIONALS.....	13

APPENDICES

Appendix A	Laboratory Analysis and Chain-of-Custody
Appendix B	Sampling Plan
Appendix C	Quality Assurance Project Plan

Executive Summary

Partner Engineering and Science, Inc. (Partner) collected drinking water samples for Jackson Township Board of Education at Memorial High School on March 5, 2022. Samples were collected according to the "New Jersey Department of Education N.J.A.C. 6A:26" requirements for testing of lead in New Jersey Schools and the "USEPA 3Ts for Reducing Lead in Drinking Water in Schools" recommendations, as well as the Safe Drinking Water Act of 1974.

The first sample at each fixture was a "first draw" which was collected directly from the fixture without letting the water run or flush. The second sample was collected after letting the water run (flush) for thirty seconds. This sample evaluates the lead in water from the water purveyor and the pipes outside the building. The samples collected were analyzed by Alpha Analytical Labs located in Mahwah, New Jersey for analysis of lead content using USEPA Method 200.8 for lead in drinking water. The action level for lead has been set at 15 parts per billion (ppb). According to the USEPA, given present technology and resources, this level is the lowest level to which water systems can reasonably be required to control this contaminant should it be present in drinking water.

Sample analysis indicated that measured lead concentrations did exceed the USEPA Action Level of 15 ppb for lead at Memorial High School. Specifically, water from the following outlets had exceedances:

- JM-WF-50, initial draw, 131.2 ppb
- JM-WF-50-F, Second draw, 161.9 ppb
- JM-WF-51, initial draw, 29.80 ppb
- JM-WF-51-F, Second draw, 16.90 ppb
- JM-WF-57, initial draw, 319.6 ppb
- JM-WF-57-F, Second draw, 349.9 ppb
- JM-WF-59, initial draw, 18.05 ppb
- JM-S-78, initial draw, 117.6 ppb
- JM-S-81, initial draw, 178.6 ppb

Based on the above referenced sample analytical results, Partner recommends the following actions:

- For the sinks exceeding the USEPA Action Level, these outlets should be labelled as "Do Not Drink – Safe for Handwashing Only".
- Remove drinking water outlets of concern from service.
- Conduct an investigation into the drinking water outlet of concern and replace any potential lead-leaching fixtures or equipment, such as fixtures and associated piping, that may be contributing to dissolved lead in drinking water.

1.0 INTRODUCTION

1.1 Property Description

Address(s):	Memorial High School – 101 Don Connor Boulevard
Nature of Use:	School
Walk-Through Inspector:	Angelica Rosaperez
Walk-Through Date:	January 12, 2022
Sampling Conducted By:	Angelica Rosaperez Anthony Mercogliano
Sampling Date:	March 5, 2022

1.2 Purpose and Scope

The purpose of this drinking water sampling event was to sample and analyze drinking water for a determination of lead content for comparison with the USEPA Action Level as defined by the National Primary Drinking Water Regulations (NPDWR - 40 CFR Chapter I, Part 141), in addition to the "New Jersey Department of Education N.J.A.C. 6A:26" requirements for testing of lead in New Jersey Schools and the "USEPA 3Ts for Reducing Lead in Drinking Water in Schools". The NPDW set a Maximum Contaminant Level Goal (MCLG) for each listed contaminant, which identifies a level of that contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety and are non-enforceable public health goals. The MCLG for lead has been set at zero (0) ppb. Since lead contamination generally occurs from corrosion of onsite lead pipes, or lead-based solder on fittings and fixtures, it cannot be directly detected or removed by the municipal water system. Instead, the USEPA is requiring municipal water systems to control the corrosiveness of their water if the level of lead at the tap exceeds an Action Level.

The action level for lead has been set at 15 parts per billion (ppb). According to the NPDWR Lead and Copper Rule (LCR), given present technology and resources, this level is the lowest level to which water systems can reasonably be required to control this contaminant should it be present in drinking water.

2.0 METHODOLOGY

Select drinking water samples were collected according to the “New Jersey Department of Education N.J.A.C. 6A:26” requirements for testing of lead in New Jersey Schools and the “USEPA 3Ts for Reducing Lead in Drinking Water in Schools” recommendations, as well as the LCR Monitoring requirements for lead in tap water (40 CFR Part 141, Subpart I, § 141.86(b)). Sampling consisted of collecting a one liter (L) first draw sample from a drinking water outlet that had been stagnant for at least eight (8) hours in a bottle with an appropriate preservative. Partner made a reasonable effort to determine whether the stagnation preconditions were able to be met prior to conducting sampling. A second-draw sample was collected minutes after the first-draw, in order to determine whether lead was being provided via the service line. Second-draw samples were only analyzed if the first-draw sample exceeded the USEPA Action Level of 15 ppb. Sample bottles were provided by Alpha Analytical Labs located in Mahwah, New Jersey with an appropriate preservative lead in drinking water sampling. After collection, sample bottles were labeled with a unique identifier and transferred under chain of custody to by Alpha Analytical Labs located in Mahwah, New Jersey for analysis by USEPA Method 200.8. The laboratory results and chain of custody are contained in **Appendix A**.

3.0 BACKGROUND

Partner collected a total of 148 drinking water samples from Memorial High School on March 2017. A total of 79 samples were analyzed. Following collection, samples were sent to SGS Accutest in Dayton, New Jersey for analysis of lead content using USEPA Method 200.8 for lead in drinking water. The results of the analytical data revealed that zero samples exceeded the USEPA Action level of 15 ppb for lead.

4.0 ANALYTICAL RESULTS

During the course of this site visit, Partner collected water samples at 86 locations. Partner did not attempt to disassemble mechanical equipment, open plumbing pipe chases, or assess materials within wall voids.

Sample names and their respective locations were updated from the 2017 sampling event based on relevant known plumbing information as provided by the Jackson Township Board of Education and the site guide.

Partner attempted to collect samples from the following outlets; however, based upon the condition of the outlet and recommendations from the site guide, a sample could not be collected at the following locations:

- **JM-WF-11, JM-WF-13, JM-WF-58, JM-WF-83, JM-S-84**

A total of 162 drinking water samples were collected from Memorial High School on March 5, 2022. A total of 87 samples were analyzed. The results are listed in Table 1 below.

Table 1 Analytical Results Summary Memorial High School March 5, 2022		
Sample Name	Location	Results (ppb)
JM-POE	Boiler Room - FA	13.38
JM-WF-01	Across Stage	0.7039
JM-WF-02	Across Stage	ND
JM-WF-03	Near 404	0.4362
JM-WF-04	Near 404	ND
JM-BF-05	Near 404	ND
JM-WF-06	Near Main Office	ND
JM-WF-07	Near Main Office	ND
JM-WF-08	Near Main Office	0.7951
JM-WF-09	Clayton GLR	6.134
JM-WF-10	Clayton GLR	4.050
JM-WF-12	Outside GLR	7.054
JM-WF-14	Clayton BLR	0.8140
JM-WF-15	Across 524	3.744
JM-S-16	Clayton Kitchen	2.436
JM-S-17	Clayton Kitchen	0.8581
JM-S-18	Room 524	ND

Table 1 Analytical Results Summary Memorial High School March 5, 2022		
Sample Name	Location	Results (ppb)
JM-S-19	Room 524	ND
JM-S-20	Room 524	0.3570
JM-S-21	Room 524	ND
JM-WF-22	Across Nurse	ND
JM-BF-23	Across Nurse	ND
JM-S-24	Nurse	0.4567
JM-WF-25	Across Rm 528	2.235
JM-S-26	Memorial FL	0.9739
JM-WF-27	Across 525	0.8099
JM-WF-28	Near Counselor	1.875
JM-WF-29	Between 504-505	0.5685
JM-WF-30	Across 521	1.848
JM-WF-31	Across 520	ND
JM-WF-32	Near 611	5.132
JM-WF-33	Near 611	2.940
JM-WF-34	Near 611 GR	1.251
JM-WF-35	Near 611 GR	2.270
JM-WF-36	Near 611 BR	1.946
JM-WF-37	Near 611 BR	1.565
JM-WF-38	Near 617 BR	0.8692
JM-WF-39	Near 617 BR	3.441
JM-WF-40	Near 617 BR	1.915
JM-WF-41	Near 617 BR	1.300
JM-WF-42	Near 618 GR	2.625
JM-WF-43	Near 618 GR	2.251
JM-WF-44	Near 618 GR	3.477
JM-WF-45	Near 618 GR	2.101
JM-S-46	Rm 617	0.4578
JM-S-47	RM 619	2.046
JM-SS-47	Teacher's Lounge	2.782
JM-WF-48	Next to Rm 206	1.048

Table 1 Analytical Results Summary Memorial High School March 5, 2022		
Sample Name	Location	Results (ppb)
JM-S-49	Nurse	1.981
JM-WF-50	Next to 204	131.2
JM-WF-50-F	Next to 204	161.9
JM-WF-51	Next to 204	29.80
JM-WF-51-F	Next to 204	16.90
JM-WF-52	Across 216	3.140
JM-WF-53	Across 216	2.825
JM-WF-54	Next to 220	4.124
JM-WF-55	Next to 220	2.135
JM-WF-56	Cross MO A-wing	6.098
JM-WF-57	Memorial Office (MO)	319.6
JM-WF-57-F	Memorial Office (MO)	349.9
JM-WF-59	Room 104 Tech	18.05
JM-WF-59-F	Room 104 Tech	2.531
JM-S-60	Room 104 Tech	2.313
JM-S-61	Library Office	1.394
JM-WF-62	Memorial B-wing	2.498
JM-S-63	Custodial Room	0.5335
JM-WF-64	Memorial Gym	3.218
JM-WF-65	Memorial Gym-GLR	3.411
JM-WF-66	Woodshop-RM 124	2.585
JM-WF-67	Weight Room 126	0.4446
JM-WF-68	Memorial Gym	ND
JM-WF-69	Across from Gym	ND
JM-BF-70	Across from Gym	ND
JM-IM-71	Kitchen	0.7480
JM-S-72	Kitchen	0.7456
JM-S-73	Kitchen	0.4026
JM-S-74	Kitchen	7.044
JM-WF-75	Across from GBR	ND
JM-WF-76	Across from GBR	ND

Table 1 Analytical Results Summary Memorial High School March 5, 2022		
Sample Name	Location	Results (ppb)
JM-IM-77	Trainer	ND
JM-S-78	Trainer	117.6
JM-S-78-F	Trainer	6.968
JM-WF-79	Across from 137	1.867
JM-IM-80	Field House – Track	0.7261
JM-S-81	Field House – Track	178.6
JM-S-81-F	Field House – Track	0.4370
JM-WF-82	Field House - Football	11.67

NOTES

ND= Not detected. Lead levels not detected at the reporting limit (0.3430 ppb)

1 ppb = 1 ug/L

BOLD = Exceedances above USEPA Action Level 15 ppb

5.0 CONCLUSION

Sample analysis indicated that measured lead concentrations did exceed the USEPA Action Level of 15 ppb for lead at Memorial High School. Specifically, water from the following outlets had exceedances:

- JM-WF-50, initial draw, 131.2 ppb
- JM-WF-50-F, Second draw, 161.9 ppb
- JM-WF-51, initial draw, 29.80 ppb
- JM-WF-51-F, Second draw, 16.90 ppb
- JM-WF-57, initial draw, 319.6 ppb
- JM-WF-57-F, Second draw, 349.9 ppb
- JM-WF-59, initial draw, 18.05 ppb
- JM-S-78, initial draw, 117.6 ppb
- JM-S-81, initial draw, 178.6 ppb

6.0 RECOMMENDATIONS

Based on the above referenced sample analytical results, Partner recommends the following actions:

- For the sinks exceeding the USEPA Action Level, these outlets should be labelled as “Do Not Drink – Safe for Handwashing Only”.
- Remove drinking water outlets of concern from service.
- Conduct an investigation into the drinking water outlet of concern and replace any potential lead-leaching fixtures or equipment, such as fixtures and associated piping, that may be contributing to dissolved lead in drinking water.

Additional control technologies may be utilized to reduce lead content in drinking water, including, but not limited to onsite water treatment and filtration. All response actions should be conducted in accordance with industry, local, state and federal guidelines and/or requirements.

In the event the remedial action involves replacing the fixture/associated piping or installing a new fixture, Jackson Township BOE should conduct sampling for lead in drinking water to ensure lead levels are below the action level prior to opening up the fixture for use. Additionally, sampling of all drinking water outlets must be conducted every third school year beginning with the 2021-2022 school year.

Flushing involves opening suspect taps every morning before the facility opens and letting the water run to remove water that has been standing in the interior pipes and/or the outlets. All flushing should be recorded in a log submitted daily to the head of maintenance/facilities. The faucet should be opened and the water should run for 30 seconds to one minute, or until cold.

A filtration device, or point-of-use (POU) device can be relatively inexpensive (\$65 to \$250) or expensive (ranging from \$250 to \$500), their effectiveness varies, and they may be vulnerable to vandalism. They also require a maintenance program for regular upkeep to ensure effectiveness. Cartridge filter units need to be replaced periodically to remain effective. NSF International, an independent, third-party certification organization, has a testing program to evaluate the performance of POU devices for lead removal (NSF Standard 53). Before purchasing any device, ask the manufacturer for proof of NSF approval and the Performance Data Sheet, or check by visiting the NSF Web site at:

http://www.nsf.org/business/search_listings/index.asp

Consult NSF Standard 61 (Sections 4, 8 and 9) before buying any replacement products. This standard will provide you with information on plumbing products that are designed to minimize lead leaching. Before you purchase any brass plumbing products, request information regarding compliance with this standard.

7.0 LIMITATIONS

Partner subcontracted with Alpha Analytical who performed the lead analysis. No warranties expressed or implied, are made by Partner or its subcontractor Alpha Analytical or their employees as to the use of any information, apparatus, product or process disclosed in this report. Every reasonable effort has been made to assure correctness.

State-of-the-art practices have been employed to perform this inspection. No demolition or product research was performed in attempts to reveal material compositions. The services consist of professional opinions and recommendations made in accordance with generally accepted engineering principles/practices. These services are designed to provide an analytical tool to assist the client. Partner and its subcontractors and their employees/representatives bear no responsibility for the actual condition of the structure or safety of this site pertaining to lead and/or lead contamination regardless of the actions taken by the inspection team or the client.

8.0 SIGNATURES OF PROFESSIONALS

Partner performed lead-in-drinking water sampling at the Jackson Township Board of Education properties, Ocean County, New Jersey in general conformance with the scope and limitations of the protocol stated earlier in this report. Exceptions to or deletions from this protocol are discussed earlier in this report.

Prepared By:

Partner Engineering and Science, Inc.



Angelica Rosaperez
Assistant Project Manager

Reviewed by:



Daniel Bracey, CSP, CHMM
Senior Project Manager

APPENDIX A: LABORATORY ANALYSIS AND CHAIN OF CUSTODY



ANALYTICAL REPORT

Lab Number:	L2211733
Client:	Partner Engineering & Science, Inc. 611 Industrial Way West Eatontown, NJ 07724
ATTN:	Angelica Rosaperez
Phone:	(732) 380-1200
Project Name:	JACKSON LDW-MEMORIAL H.S
Project Number:	Not Specified
Report Date:	03/28/22

The original project report/data package is held by Alpha Analytical. This report/data package is paginated and should be reproduced only in its entirety. Alpha Analytical holds no responsibility for results and/or data that are not consistent with the original.

Certifications & Approvals: MA (M-MA086), NH NELAP (2064), CT (PH-0574), IL (200077), ME (MA00086), MD (348), NJ (MA935), NY (11148), NC (25700/666), PA (68-03671), RI (LAO00065), TX (T104704476), VT (VT-0935), VA (460195), USDA (Permit #P330-17-00196).

Eight Walkup Drive, Westborough, MA 01581-1019
508-898-9220 (Fax) 508-898-9193 800-624-9220 - www.alphalab.com



Project Name: JACKSON LDW-MEMORIAL H.S
Project Number: Not Specified

Lab Number: L2211733
Report Date: 03/28/22

Alpha Sample ID	Client ID	Matrix	Sample Location	Collection Date/Time	Receive Date
L2211733-01	JM-POE	DW	JACKSON	03/05/22 08:28	03/07/22
L2211733-02	JM-POE-F	DW	JACKSON	03/05/22 08:29	03/07/22
L2211733-03	JM-WF-01	DW	JACKSON	03/05/22 08:30	03/07/22
L2211733-04	JM-WF-01-F	DW	JACKSON	03/05/22 08:31	03/07/22
L2211733-05	JM-WF-02	DW	JACKSON	03/05/22 08:32	03/07/22
L2211733-06	JM-WF-02-F	DW	JACKSON	03/05/22 08:33	03/07/22
L2211733-07	JM-WF-03	DW	JACKSON	03/05/22 08:35	03/07/22
L2211733-08	JM-WF-03-F	DW	JACKSON	03/05/22 08:36	03/07/22
L2211733-09	JM-WF-04	DW	JACKSON	03/05/22 08:37	03/07/22
L2211733-10	JM-WF-04-F	DW	JACKSON	03/05/22 08:38	03/07/22
L2211733-11	JM-BF-05	DW	JACKSON	03/05/22 08:37	03/07/22
L2211733-12	JM-BF-05-F	DW	JACKSON	03/05/22 08:37	03/07/22
L2211733-13	JM-WF-06	DW	JACKSON	03/05/22 08:45	03/07/22
L2211733-14	JM-WF-06-F	DW	JACKSON	03/05/22 08:46	03/07/22
L2211733-15	JM-WF-07	DW	JACKSON	03/05/22 08:47	03/07/22
L2211733-16	JM-WF-07-F	DW	JACKSON	03/05/22 08:48	03/07/22
L2211733-17	JM-WF-08	DW	JACKSON	03/05/22 08:49	03/07/22
L2211733-18	JM-WF-08-F	DW	JACKSON	03/05/22 08:50	03/07/22
L2211733-19	JM-WF-09	DW	JACKSON	03/05/22 08:51	03/07/22
L2211733-20	JM-WF-09-F	DW	JACKSON	03/05/22 08:52	03/07/22
L2211733-21	JM-WF-10	DW	JACKSON	03/05/22 08:53	03/07/22
L2211733-22	JM-WF-10-F	DW	JACKSON	03/05/22 08:54	03/07/22
L2211733-23	JM-WF-12	DW	JACKSON	03/05/22 08:55	03/07/22
L2211733-24	JM-WF-12-F	DW	JACKSON	03/05/22 08:56	03/07/22

Alpha Sample ID	Client ID	Matrix	Sample Location	Collection Date/Time	Receive Date
L2211733-25	JM-WF-14	DW	JACKSON	03/05/22 09:00	03/07/22
L2211733-26	JM-WF-14-F	DW	JACKSON	03/05/22 09:02	03/07/22
L2211733-27	JM-WF-15	DW	JACKSON	03/05/22 09:05	03/07/22
L2211733-28	JM-WF-15-F	DW	JACKSON	03/05/22 09:06	03/07/22
L2211733-29	JM-S-16	DW	JACKSON	03/05/22 09:09	03/07/22
L2211733-30	JM-S-16-F	DW	JACKSON	03/05/22 09:10	03/07/22
L2211733-31	JM-S-17	DW	JACKSON	03/05/22 09:11	03/07/22
L2211733-32	JM-S-17-F	DW	JACKSON	03/05/22 09:12	03/07/22
L2211733-33	JM-S-18	DW	JACKSON	03/05/22 09:13	03/07/22
L2211733-34	JM-S-18-F	DW	JACKSON	03/05/22 09:14	03/07/22
L2211733-35	JM-S-19	DW	JACKSON	03/05/22 09:15	03/07/22
L2211733-36	JM-S-19-F	DW	JACKSON	03/05/22 09:16	03/07/22
L2211733-37	JM-S-20	DW	JACKSON	03/05/22 09:17	03/07/22
L2211733-38	JM-S-20-F	DW	JACKSON	03/05/22 09:18	03/07/22
L2211733-39	JM-S-21	DW	JACKSON	03/05/22 09:19	03/07/22
L2211733-40	JM-S-21-F	DW	JACKSON	03/05/22 09:20	03/07/22
L2211733-41	JM-WF-22	DW	JACKSON	03/05/22 09:21	03/07/22
L2211733-42	JM-WF-22-F	DW	JACKSON	03/05/22 09:22	03/07/22
L2211733-43	JM-BF-23	DW	JACKSON	03/05/22 09:21	03/07/22
L2211733-44	JM-BF-23-F	DW	JACKSON	03/05/22 09:22	03/07/22
L2211733-45	JM-S-24	DW	JACKSON	03/05/22 09:23	03/07/22
L2211733-46	JM-S-24-F	DW	JACKSON	03/05/22 09:24	03/07/22
L2211733-47	JM-WF-25	DW	JACKSON	03/05/22 09:25	03/07/22
L2211733-48	JM-WF-25-F	DW	JACKSON	03/05/22 09:26	03/07/22
L2211733-49	JM-S-26	DW	JACKSON	03/05/22 09:27	03/07/22
L2211733-50	JM-S-26-F	DW	JACKSON	03/05/22 09:28	03/07/22
L2211733-51	JM-WF-27	DW	JACKSON	03/05/22 09:29	03/07/22
L2211733-52	JM-WF-27-F	DW	JACKSON	03/05/22 09:30	03/07/22



Alpha Sample ID	Client ID	Matrix	Sample Location	Collection Date/Time	Receive Date
L2211733-53	JM-WF-28	DW	JACKSON	03/05/22 09:31	03/07/22
L2211733-54	JM-WF-28-F	DW	JACKSON	03/05/22 09:32	03/07/22
L2211733-55	JM-WF-29	DW	JACKSON	03/05/22 09:34	03/07/22
L2211733-56	JM-WF-29-F	DW	JACKSON	03/05/22 09:35	03/07/22
L2211733-57	JM-WF-30	DW	JACKSON	03/05/22 09:37	03/07/22
L2211733-58	JM-WF-30-F	DW	JACKSON	03/05/22 09:38	03/07/22
L2211733-59	JM-WF-31	DW	JACKSON	03/05/22 09:39	03/07/22
L2211733-60	JM-WF-31-F	DW	JACKSON	03/05/22 09:40	03/07/22
L2211733-61	JM-WF-32	DW	JACKSON	03/05/22 09:45	03/07/22
L2211733-62	JM-WF-32-F	DW	JACKSON	03/05/22 09:46	03/07/22
L2211733-63	JM-WF-33	DW	JACKSON	03/05/22 09:47	03/07/22
L2211733-64	JM-WF-33-F	DW	JACKSON	03/05/22 09:48	03/07/22
L2211733-65	JM-WF-34	DW	JACKSON	03/05/22 09:49	03/07/22
L2211733-66	JM-WF-34-F	DW	JACKSON	03/05/22 09:50	03/07/22
L2211733-67	JM-WF-35	DW	JACKSON	03/05/22 09:51	03/07/22
L2211733-68	JM-WF-35-F	DW	JACKSON	03/05/22 09:52	03/07/22
L2211733-69	JM-WF-36	DW	JACKSON	03/05/22 09:53	03/07/22
L2211733-70	JM-WF-36-F	DW	JACKSON	03/05/22 09:54	03/07/22
L2211733-71	JM-WF-37	DW	JACKSON	03/05/22 09:55	03/07/22
L2211733-72	JM-WF-37-F	DW	JACKSON	03/05/22 09:56	03/07/22
L2211733-73	JM-WF-38	DW	JACKSON	03/05/22 09:59	03/07/22
L2211733-74	JM-WF-38-F	DW	JACKSON	03/05/22 10:00	03/07/22
L2211733-75	JM-WF-39	DW	JACKSON	03/05/22 10:01	03/07/22
L2211733-76	JM-WF-39-F	DW	JACKSON	03/05/22 10:02	03/07/22
L2211733-77	JM-WF-40	DW	JACKSON	03/05/22 10:03	03/07/22
L2211733-78	JM-WF-40-F	DW	JACKSON	03/05/22 10:04	03/07/22
L2211733-79	JM-WF-41	DW	JACKSON	03/05/22 10:05	03/07/22
L2211733-80	JM-WF-41-F	DW	JACKSON	03/05/22 10:06	03/07/22



Alpha Sample ID	Client ID	Matrix	Sample Location	Collection	
				Date/Time	Receive Date
L2211733-81	JM-WF-42	DW	JACKSON	03/05/22 10:07	03/07/22
L2211733-82	JM-WF-42-F	DW	JACKSON	03/05/22 10:08	03/07/22
L2211733-83	JM-WF-43	DW	JACKSON	03/05/22 10:00	03/07/22
L2211733-84	JM-WF-43-F	DW	JACKSON	03/05/22 10:10	03/07/22
L2211733-85	JM-WF-44	DW	JACKSON	03/05/22 10:11	03/07/22
L2211733-86	JM-WF-44-F	DW	JACKSON	03/05/22 10:12	03/07/22
L2211733-87	JM-WF-45	DW	JACKSON	03/05/22 10:13	03/07/22
L2211733-88	JM-WF-45-F	DW	JACKSON	03/05/22 10:14	03/07/22
L2211733-89	JM-S-46	DW	JACKSON	03/05/22 10:15	03/07/22
L2211733-90	JM-S-46-F	DW	JACKSON	03/05/22 10:16	03/07/22
L2211733-91	JM-S-47	DW	JACKSON	03/05/22 10:17	03/07/22
L2211733-92	JM-S-47-F	DW	JACKSON	03/05/22 10:18	03/07/22
L2211733-93	JM-SS-47	DW	JACKSON	03/05/22 10:19	03/07/22
L2211733-94	JM-SS-47-F	DW	JACKSON	03/05/22 10:20	03/07/22
L2211733-95	JM-WF-48	DW	JACKSON	03/05/22 10:22	03/07/22
L2211733-96	JM-WF-48-F	DW	JACKSON	03/05/22 10:23	03/07/22
L2211733-97	JM-S-49	DW	JACKSON	03/05/22 10:25	03/07/22
L2211733-98	JM-S-49-F	DW	JACKSON	03/05/22 10:26	03/07/22
L2211733-99	JM-WF-50	DW	JACKSON	03/05/22 10:27	03/07/22
L2211733-100	JM-WF-50-F	DW	JACKSON	03/05/22 10:28	03/07/22
L2211733-101	JM-WF-51	DW	JACKSON	03/05/22 10:29	03/07/22
L2211733-102	JM-WF-51-F	DW	JACKSON	03/05/22 10:30	03/07/22
L2211733-103	JM-WF-52	DW	JACKSON	03/05/22 10:31	03/07/22
L2211733-104	JM-WF-52-F	DW	JACKSON	03/05/22 10:32	03/07/22
L2211733-105	JM-WF-53	DW	JACKSON	03/05/22 10:33	03/07/22
L2211733-106	JM-WF-53-F	DW	JACKSON	03/05/22 10:34	03/07/22
L2211733-107	JM-WF-54	DW	JACKSON	03/05/22 10:35	03/07/22
L2211733-108	JM-WF-54-F	DW	JACKSON	03/05/22 10:36	03/07/22

Alpha Sample ID	Client ID	Matrix	Sample Location	Collection Date/Time	Receive Date
L2211733-109	JM-WF-55	DW	JACKSON	03/05/22 10:37	03/07/22
L2211733-110	JM-WF-55-F	DW	JACKSON	03/05/22 10:38	03/07/22
L2211733-111	JM-WF-56	DW	JACKSON	03/05/22 10:45	03/07/22
L2211733-112	JM-WF-56-F	DW	JACKSON	03/05/22 10:46	03/07/22
L2211733-113	JM-WF-57	DW	JACKSON	03/05/22 10:47	03/07/22
L2211733-114	JM-WF-57-F	DW	JACKSON	03/05/22 10:48	03/07/22
L2211733-115	JM-WF-59	DW	JACKSON	03/05/22 10:52	03/07/22
L2211733-116	JM-WF-59-F	DW	JACKSON	03/05/22 10:53	03/07/22
L2211733-117	JM-S-60	DW	JACKSON	03/05/22 10:54	03/07/22
L2211733-118	JM-S-60-F	DW	JACKSON	03/05/22 10:55	03/07/22
L2211733-119	JM-S-61	DW	JACKSON	03/05/22 10:57	03/07/22
L2211733-120	JM-S-61-F	DW	JACKSON	03/05/22 10:58	03/07/22
L2211733-121	JM-WF-62	DW	JACKSON	03/05/22 11:01	03/07/22
L2211733-122	JM-WF-62-F	DW	JACKSON	03/05/22 11:02	03/07/22
L2211733-123	JM-S-63	DW	JACKSON	03/05/22 11:03	03/07/22
L2211733-124	JM-S-63-F	DW	JACKSON	03/05/22 11:04	03/07/22
L2211733-125	JM-WF-64	DW	JACKSON	03/05/22 11:06	03/07/22
L2211733-126	JM-WF-64-F	DW	JACKSON	03/05/22 11:07	03/07/22
L2211733-127	JM-WF-65	DW	JACKSON	03/05/22 11:11	03/07/22
L2211733-128	JM-WF-65-F	DW	JACKSON	03/05/22 11:12	03/07/22
L2211733-129	JM-WF-66	DW	JACKSON	03/05/22 11:13	03/07/22
L2211733-130	JM-WF-66-F	DW	JACKSON	03/05/22 11:14	03/07/22
L2211733-131	JM-WF-67	DW	JACKSON	03/05/22 11:15	03/07/22
L2211733-132	JM-WF-67-F	DW	JACKSON	03/05/22 11:16	03/07/22
L2211733-133	JM-WF-68	DW	JACKSON	03/05/22 11:18	03/07/22
L2211733-134	JM-WF-68-F	DW	JACKSON	03/05/22 11:19	03/07/22
L2211733-135	JM-WF-69	DW	JACKSON	03/05/22 11:23	03/07/22
L2211733-136	JM-WF-69-F	DW	JACKSON	03/05/22 11:34	03/07/22

Alpha Sample ID	Client ID	Matrix	Sample Location	Collection Date/Time	Receive Date
L2211733-137	JM-BF-70	DW	JACKSON	03/05/22 11:23	03/07/22
L2211733-138	JM-BF-70-F	DW	JACKSON	03/05/22 11:24	03/07/22
L2211733-139	JM-1M-71	DW	JACKSON	03/05/22 11:25	03/07/22
L2211733-140	JM-1M-71-F	DW	JACKSON	03/05/22 11:26	03/07/22
L2211733-141	JM-S-72	DW	JACKSON	03/05/22 11:27	03/07/22
L2211733-142	JM-S-72-F	DW	JACKSON	03/05/22 11:28	03/07/22
L2211733-143	JM-S-73	DW	JACKSON	03/05/22 11:29	03/07/22
L2211733-144	JM-S-73-F	DW	JACKSON	03/05/22 11:30	03/07/22
L2211733-145	JM-S-74	DW	JACKSON	03/05/22 11:31	03/07/22
L2211733-146	JM-S-74-F	DW	JACKSON	03/05/22 11:32	03/07/22
L2211733-147	JM-WF-75	DW	JACKSON	03/05/22 11:35	03/07/22
L2211733-148	JM-WF-75-F	DW	JACKSON	03/05/22 11:36	03/07/22
L2211733-149	JM-WF-76	DW	JACKSON	03/05/22 11:37	03/07/22
L2211733-150	JM-WF-76-F	DW	JACKSON	03/05/22 11:38	03/07/22
L2211733-151	JM-1M-77	DW	JACKSON	03/05/22 11:39	03/07/22
L2211733-152	JM-1M-77-F	DW	JACKSON	03/05/22 11:40	03/07/22
L2211733-153	JM-S-78	DW	JACKSON	03/05/22 11:41	03/07/22
L2211733-154	JM-S-78-F	DW	JACKSON	03/05/22 11:42	03/07/22
L2211733-155	JM-WF-79	DW	JACKSON	03/05/22 11:43	03/07/22
L2211733-156	JM-WF-79-F	DW	JACKSON	03/05/22 11:44	03/07/22
L2211733-157	JM-1M-80	DW	JACKSON	03/05/22 11:52	03/07/22
L2211733-158	JM-1M-80-F	DW	JACKSON	03/05/22 11:53	03/07/22
L2211733-159	JM-S-81	DW	JACKSON	03/05/22 11:54	03/07/22
L2211733-160	JM-S-81-F	DW	JACKSON	03/05/22 11:55	03/07/22
L2211733-161	JM-WF-82	DW	JACKSON	03/05/22 12:02	03/07/22
L2211733-162	JM-WF-82-F	DW	JACKSON	03/05/22 12:03	03/07/22

Project Name: JACKSON LDW-MEMORIAL H.S
Project Number: Not Specified

Lab Number: L2211733
Report Date: 03/28/22

**NJ DEP Data of Known Quality Protocols
 Conformance/Non-Conformance
 Summary Questionnaire**

1	For each analytical method referenced in this laboratory report package, were all specified QA/QC performance criteria followed, including the requirement to explain any criteria falling outside of acceptable guidelines, as specified in the NJDEP Data of Known Quality performance standards?	YES
1a	Were the method specified handling, preservation, and holding time requirements met?	YES
1b	EPH Method: Was the EPH Method conducted without significant modifications (see Section 11.3 of respective DKQ methods)?	N/A
2	Were all samples received by the laboratory in a condition consistent with that described on the associated chain-of-custody document(s)?	YES
3	Were all samples received at an appropriate temperature ($4 \pm 2^{\circ} \text{C}$)?	YES
4	Were all QA/QC performance criteria specified in the NJDEP DKQP standards achieved?	YES
5a	Were reporting limits specified or referenced on the chain-of-custody or communicated to the laboratory prior to sample receipt?	NO
5b	Were these reporting limits met?	N/A
6	For each analytical method referenced in this laboratory report package, were results reported for all constituents identified in the method-specific analyte lists presented in the DKQP documents and/or site-specific QAPP?	YES
7	Are project-specific matrix spikes and/or laboratory duplicates included in this data set?	NO

Note: For all questions to which the response was "No" (with the exception of question #7), additional information must be provided in an attached narrative. If the answer to question #1, #1a or #1b is "No", the data package does not meet the requirements for "Data of Known Quality".

Project Name: JACKSON LDW-MEMORIAL H.S
Project Number: Not Specified

Lab Number: L2211733
Report Date: 03/28/22

Case Narrative

The samples were received in accordance with the Chain of Custody and no significant deviations were encountered during the preparation or analysis unless otherwise noted. Sample Receipt, Container Information, and the Chain of Custody are located at the back of the report.

Results contained within this report relate only to the samples submitted under this Alpha Lab Number and meet NELAP requirements for all NELAP accredited parameters unless otherwise noted in the following narrative. The data presented in this report is organized by parameter (i.e. VOC, SVOC, etc.). Sample specific Quality Control data (i.e. Surrogate Spike Recovery) is reported at the end of the target analyte list for each individual sample, followed by the Laboratory Batch Quality Control at the end of each parameter. Tentatively Identified Compounds (TICs), if requested, are reported for compounds identified to be present and are not part of the method/program Target Compound List, even if only a subset of the TCL are being reported. If a sample was re-analyzed or re-extracted due to a required quality control corrective action and if both sets of data are reported, the Laboratory ID of the re-analysis or re-extraction is designated with an "R" or "RE", respectively.

When multiple Batch Quality Control elements are reported (e.g. more than one LCS), the associated samples for each element are noted in the grey shaded header line of each data table. Any Laboratory Batch, Sample Specific % recovery or RPD value that is outside the listed Acceptance Criteria is bolded in the report. In reference to questions H (CAM) or 4 (RCP) when "NO" is checked, the performance criteria for CAM and RCP methods allow for some quality control failures to occur and still be within method compliance. In these instances, the specific failure is not narrated but noted in the associated QC Outlier Summary Report, located directly after the Case Narrative. QC information is also incorporated in the Data Usability Assessment table (Format 11) of our Data Merger tool, where it can be reviewed in conjunction with the sample result, associated regulatory criteria and any associated data usability implications.

Soil/sediments, solids and tissues are reported on a dry weight basis unless otherwise noted. Definitions of all data qualifiers and acronyms used in this report are provided in the Glossary located at the back of the report.

HOLD POLICY - For samples submitted on hold, Alpha's policy is to hold samples (with the exception of Air canisters) free of charge for 21 calendar days from the date the project is completed. After 21 calendar days, we will dispose of all samples submitted including those put on hold unless you have contacted your Alpha Project Manager and made arrangements for Alpha to continue to hold the samples. Air canisters will be disposed after 3 business days from the date the project is completed.

Please contact Project Management at 800-624-9220 with any questions.

Project Name: JACKSON LDW-MEMORIAL H.S
Project Number: Not Specified

Lab Number: L2211733
Report Date: 03/28/22

Case Narrative (continued)

Report Submission

All non-detect (ND) or estimated concentrations (J-qualified) have been quantitated to the limit noted in the MDL column.

DKQP Related Narratives

Report Submission

In reference to question 5a:

Reporting limits were not specified.

I, the undersigned, attest under the pains and penalties of perjury that, to the best of my knowledge and belief and based upon my personal inquiry of those responsible for providing the information contained in this analytical report, such information is accurate and complete. This certificate of analysis is not complete unless this page accompanies any and all pages of this report.

Authorized Signature:

 Caitlin Walukevich

Title: Technical Director/Representative

Date: 03/28/22

METALS

Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-01

Date Collected: 03/05/22 08:28

Client ID: JM-POE

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	13.38		ug/l	1.000	0.3430	1	03/09/22 09:14	03/09/22 21:22	EPA 3005A	3,200.8	CD



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-03

Date Collected: 03/05/22 08:30

Client ID: JM-WF-01

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.7039	J	ug/l	1.000	0.3430	1	03/11/22 10:04	03/13/22 22:26	EPA 3005A	3,200.8	WP



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-05

Date Collected: 03/05/22 08:32

Client ID: JM-WF-02

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		ug/l	1.000	0.3430	1	03/11/22 10:04	03/13/22 23:06	EPA 3005A	3,200.8	WP



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-07

Date Collected: 03/05/22 08:35

Client ID: JM-WF-03

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.4362	J	ug/l	1.000	0.3430	1	03/11/22 10:04	03/13/22 22:46	EPA 3005A	3,200.8	WP



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-09

Date Collected: 03/05/22 08:37

Client ID: JM-WF-04

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		ug/l	1.000	0.3430	1	03/11/22 10:04	03/13/22 23:10	EPA 3005A	3,200.8	WP



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-11

Date Collected: 03/05/22 08:37

Client ID: JM-BF-05

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		ug/l	1.000	0.3430	1	03/11/22 10:04	03/13/22 23:14	EPA 3005A	3,200.8	WP



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-13

Date Collected: 03/05/22 08:45

Client ID: JM-WF-06

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		ug/l	1.000	0.3430	1	03/11/22 10:04	03/13/22 23:18	EPA 3005A	3,200.8	WP



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-15

Date Collected: 03/05/22 08:47

Client ID: JM-WF-07

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		ug/l	1.000	0.3430	1	03/11/22 10:04	03/13/22 23:22	EPA 3005A	3,200.8	WP



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-17

Date Collected: 03/05/22 08:49

Client ID: JM-WF-08

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.7951	J	ug/l	1.000	0.3430	1	03/11/22 10:04	03/13/22 23:26	EPA 3005A	3,200.8	WP



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-19

Date Collected: 03/05/22 08:51

Client ID: JM-WF-09

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	6.134		ug/l	1.000	0.3430	1	03/11/22 10:04	03/13/22 23:30	EPA 3005A	3,200.8	WP



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-21

Date Collected: 03/05/22 08:53

Client ID: JM-WF-10

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	4.050		ug/l	1.000	0.3430	1	03/11/22 10:04	03/13/22 23:34	EPA 3005A	3,200.8	WP



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-23

Date Collected: 03/05/22 08:55

Client ID: JM-WF-12

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	7.054		ug/l	1.000	0.3430	1	03/11/22 10:04	03/13/22 23:46	EPA 3005A	3,200.8	WP



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-25

Date Collected: 03/05/22 09:00

Client ID: JM-WF-14

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.8140	J	ug/l	1.000	0.3430	1	03/11/22 10:04	03/13/22 23:50	EPA 3005A	3,200.8	WP



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-27

Date Collected: 03/05/22 09:05

Client ID: JM-WF-15

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	3.744		ug/l	1.000	0.3430	1	03/11/22 10:04	03/13/22 23:54	EPA 3005A	3,200.8	WP



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-29

Date Collected: 03/05/22 09:09

Client ID: JM-S-16

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	2.436		ug/l	1.000	0.3430	1	03/11/22 10:04	03/13/22 23:58	EPA 3005A	3,200.8	WP



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-31

Date Collected: 03/05/22 09:11

Client ID: JM-S-17

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.8581	J	ug/l	1.000	0.3430	1	03/11/22 10:04	03/14/22 00:02	EPA 3005A	3,200.8	WP



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-33

Date Collected: 03/05/22 09:13

Client ID: JM-S-18

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		ug/l	1.000	0.3430	1	03/11/22 10:04	03/14/22 00:06	EPA 3005A	3,200.8	WP



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-35

Date Collected: 03/05/22 09:15

Client ID: JM-S-19

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		ug/l	1.000	0.3430	1	03/11/22 10:04	03/14/22 00:10	EPA 3005A	3,200.8	WP



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-37

Date Collected: 03/05/22 09:17

Client ID: JM-S-20

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.3570	J	ug/l	1.000	0.3430	1	03/11/22 10:04	03/14/22 00:14	EPA 3005A	3,200.8	WP



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-39

Date Collected: 03/05/22 09:19

Client ID: JM-S-21

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		ug/l	1.000	0.3430	1	03/11/22 10:04	03/14/22 00:18	EPA 3005A	3,200.8	WP



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-41

Date Collected: 03/05/22 09:21

Client ID: JM-WF-22

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		ug/l	1.000	0.3430	1	03/11/22 10:04	03/14/22 00:22	EPA 3005A	3,200.8	WP



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-43

Date Collected: 03/05/22 09:21

Client ID: JM-BF-23

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		ug/l	1.000	0.3430	1	03/11/22 10:28	03/14/22 11:01	EPA 3005A	3,200.8	SV



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-45

Date Collected: 03/05/22 09:23

Client ID: JM-S-24

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.4567	J	ug/l	1.000	0.3430	1	03/11/22 10:28	03/14/22 11:38	EPA 3005A	3,200.8	SV



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-47

Date Collected: 03/05/22 09:25

Client ID: JM-WF-25

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	2.235		ug/l	1.000	0.3430	1	03/11/22 10:28	03/14/22 11:06	EPA 3005A	3,200.8	SV



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-49

Date Collected: 03/05/22 09:27

Client ID: JM-S-26

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.9739	J	ug/l	1.000	0.3430	1	03/11/22 10:28	03/14/22 11:43	EPA 3005A	3,200.8	SV



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-51

Date Collected: 03/05/22 09:29

Client ID: JM-WF-27

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.8099	J	ug/l	1.000	0.3430	1	03/11/22 10:28	03/14/22 11:48	EPA 3005A	3,200.8	SV



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-53

Date Collected: 03/05/22 09:31

Client ID: JM-WF-28

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	1.875		ug/l	1.000	0.3430	1	03/11/22 10:28	03/14/22 11:53	EPA 3005A	3,200.8	SV



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-55

Date Collected: 03/05/22 09:34

Client ID: JM-WF-29

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.5685	J	ug/l	1.000	0.3430	1	03/11/22 10:28	03/14/22 11:58	EPA 3005A	3,200.8	SV



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-57

Date Collected: 03/05/22 09:37

Client ID: JM-WF-30

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	1.848		ug/l	1.000	0.3430	1	03/11/22 10:28	03/14/22 12:03	EPA 3005A	3,200.8	SV



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-59

Date Collected: 03/05/22 09:39

Client ID: JM-WF-31

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		ug/l	1.000	0.3430	1	03/11/22 10:28	03/14/22 12:08	EPA 3005A	3,200.8	SV



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-61

Date Collected: 03/05/22 09:45

Client ID: JM-WF-32

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	5.132		ug/l	1.000	0.3430	1	03/11/22 10:28	03/14/22 12:13	EPA 3005A	3,200.8	SV



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-63

Date Collected: 03/05/22 09:47

Client ID: JM-WF-33

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	2.940		ug/l	1.000	0.3430	1	03/11/22 10:28	03/14/22 12:31	EPA 3005A	3,200.8	SV



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-65

Date Collected: 03/05/22 09:49

Client ID: JM-WF-34

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	1.251		ug/l	1.000	0.3430	1	03/11/22 10:28	03/14/22 12:36	EPA 3005A	3,200.8	SV



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-67

Date Collected: 03/05/22 09:51

Client ID: JM-WF-35

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	2.270		ug/l	1.000	0.3430	1	03/11/22 10:28	03/14/22 12:41	EPA 3005A	3,200.8	SV



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-69

Date Collected: 03/05/22 09:53

Client ID: JM-WF-36

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	1.946		ug/l	1.000	0.3430	1	03/11/22 10:28	03/14/22 12:46	EPA 3005A	3,200.8	SV



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-71

Date Collected: 03/05/22 09:55

Client ID: JM-WF-37

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	1.565		ug/l	1.000	0.3430	1	03/11/22 10:28	03/14/22 12:51	EPA 3005A	3,200.8	SV



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-73

Date Collected: 03/05/22 09:59

Client ID: JM-WF-38

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.8692	J	ug/l	1.000	0.3430	1	03/11/22 10:28	03/14/22 12:56	EPA 3005A	3,200.8	SV



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-75

Date Collected: 03/05/22 10:01

Client ID: JM-WF-39

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	3.441		ug/l	1.000	0.3430	1	03/11/22 10:28	03/14/22 13:02	EPA 3005A	3,200.8	SV



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-77

Date Collected: 03/05/22 10:03

Client ID: JM-WF-40

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	1.915		ug/l	1.000	0.3430	1	03/11/22 10:28	03/14/22 13:07	EPA 3005A	3,200.8	SV



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-79

Date Collected: 03/05/22 10:05

Client ID: JM-WF-41

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	1.300		ug/l	1.000	0.3430	1	03/11/22 10:28	03/14/22 13:12	EPA 3005A	3,200.8	SV



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-81

Date Collected: 03/05/22 10:07

Client ID: JM-WF-42

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	2.625		ug/l	1.000	0.3430	1	03/11/22 10:28	03/14/22 13:17	EPA 3005A	3,200.8	SV



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-83

Date Collected: 03/05/22 10:00

Client ID: JM-WF-43

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	2.251		ug/l	1.000	0.3430	1	03/11/22 10:40	03/14/22 15:43	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-85

Date Collected: 03/05/22 10:11

Client ID: JM-WF-44

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	3.477		ug/l	1.000	0.3430	1	03/11/22 10:40	03/14/22 15:58	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-87

Date Collected: 03/05/22 10:13

Client ID: JM-WF-45

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	2.101		ug/l	1.000	0.3430	1	03/11/22 10:40	03/14/22 17:36	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-89

Date Collected: 03/05/22 10:15

Client ID: JM-S-46

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.4578	J	ug/l	1.000	0.3430	1	03/11/22 10:40	03/14/22 17:41	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-91

Date Collected: 03/05/22 10:17

Client ID: JM-S-47

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	2.046		ug/l	1.000	0.3430	1	03/11/22 10:40	03/14/22 17:46	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-93

Date Collected: 03/05/22 10:19

Client ID: JM-SS-47

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	2.782		ug/l	1.000	0.3430	1	03/11/22 10:40	03/14/22 17:51	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-95

Date Collected: 03/05/22 10:22

Client ID: JM-WF-48

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	1.048		ug/l	1.000	0.3430	1	03/11/22 10:40	03/14/22 17:56	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-97

Date Collected: 03/05/22 10:25

Client ID: JM-S-49

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	1.981		ug/l	1.000	0.3430	1	03/11/22 10:40	03/14/22 18:01	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-99

Date Collected: 03/05/22 10:27

Client ID: JM-WF-50

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	131.2		ug/l	1.000	0.3430	1	03/11/22 10:40	03/14/22 18:07	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-100

Date Collected: 03/05/22 10:28

Client ID: JM-WF-50-F

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	161.9		ug/l	10.00	3.430	10	03/16/22 07:46	03/17/22 14:05	EPA 3005A	3,200.8	CD



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-101

Date Collected: 03/05/22 10:29

Client ID: JM-WF-51

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	29.80		ug/l	1.000	0.3430	1	03/11/22 10:40	03/14/22 16:29	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-102

Date Collected: 03/05/22 10:30

Client ID: JM-WF-51-F

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	16.90		ug/l	1.000	0.3430	1	03/16/22 07:46	03/16/22 23:20	EPA 3005A	3,200.8	WP



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-103

Date Collected: 03/05/22 10:31

Client ID: JM-WF-52

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	3.140		ug/l	1.000	0.3430	1	03/11/22 10:40	03/14/22 16:34	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-105

Date Collected: 03/05/22 10:33

Client ID: JM-WF-53

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	2.825		ug/l	1.000	0.3430	1	03/11/22 10:40	03/14/22 16:39	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-107

Date Collected: 03/05/22 10:35

Client ID: JM-WF-54

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	4.124		ug/l	1.000	0.3430	1	03/11/22 10:40	03/14/22 16:44	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-109

Date Collected: 03/05/22 10:37

Client ID: JM-WF-55

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	2.135		ug/l	1.000	0.3430	1	03/11/22 10:40	03/14/22 16:49	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-111

Date Collected: 03/05/22 10:45

Client ID: JM-WF-56

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	6.098		ug/l	1.000	0.3430	1	03/11/22 10:40	03/14/22 16:55	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-113

Date Collected: 03/05/22 10:47

Client ID: JM-WF-57

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	319.6		ug/l	1.000	0.3430	1	03/11/22 10:40	03/14/22 17:00	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-114

Date Collected: 03/05/22 10:48

Client ID: JM-WF-57-F

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	349.9		ug/l	10.00	3.430	10	03/16/22 07:46	03/17/22 14:08	EPA 3005A	3,200.8	CD



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-115

Date Collected: 03/05/22 10:52

Client ID: JM-WF-59

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	18.05		ug/l	1.000	0.3430	1	03/11/22 10:40	03/14/22 17:05	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-116

Date Collected: 03/05/22 10:53

Client ID: JM-WF-59-F

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	2.531		ug/l	1.000	0.3430	1	03/16/22 07:46	03/16/22 23:26	EPA 3005A	3,200.8	WP



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-117

Date Collected: 03/05/22 10:54

Client ID: JM-S-60

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	2.313		ug/l	1.000	0.3430	1	03/11/22 10:40	03/14/22 17:10	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-119

Date Collected: 03/05/22 10:57

Client ID: JM-S-61

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	1.394		ug/l	1.000	0.3430	1	03/11/22 10:40	03/14/22 17:15	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-121

Date Collected: 03/05/22 11:01

Client ID: JM-WF-62

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	2.498		ug/l	1.000	0.3430	1	03/11/22 10:40	03/14/22 17:31	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-123

Date Collected: 03/05/22 11:03

Client ID: JM-S-63

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.5335	J	ug/l	1.000	0.3430	1	03/13/22 02:48	03/14/22 18:53	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-125

Date Collected: 03/05/22 11:06

Client ID: JM-WF-64

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	3.218		ug/l	1.000	0.3430	1	03/13/22 02:48	03/14/22 19:08	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-127

Date Collected: 03/05/22 11:11

Client ID: JM-WF-65

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	3.411		ug/l	1.000	0.3430	1	03/13/22 02:48	03/14/22 18:12	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-129

Date Collected: 03/05/22 11:13

Client ID: JM-WF-66

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	2.585		ug/l	1.000	0.3430	1	03/13/22 02:48	03/14/22 18:17	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-131

Date Collected: 03/05/22 11:15

Client ID: JM-WF-67

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.4446	J	ug/l	1.000	0.3430	1	03/13/22 02:48	03/14/22 19:14	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-133

Date Collected: 03/05/22 11:18

Client ID: JM-WF-68

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		ug/l	1.000	0.3430	1	03/13/22 02:48	03/14/22 19:19	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-135

Date Collected: 03/05/22 11:23

Client ID: JM-WF-69

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		ug/l	1.000	0.3430	1	03/13/22 02:48	03/14/22 19:38	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-137

Date Collected: 03/05/22 11:23

Client ID: JM-BF-70

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		ug/l	1.000	0.3430	1	03/13/22 02:48	03/14/22 19:44	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-139

Date Collected: 03/05/22 11:25

Client ID: JM-1M-71

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.7480	J	ug/l	1.000	0.3430	1	03/13/22 02:48	03/14/22 19:49	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-141

Date Collected: 03/05/22 11:27

Client ID: JM-S-72

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.7456	J	ug/l	1.000	0.3430	1	03/13/22 02:48	03/14/22 19:54	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-143

Date Collected: 03/05/22 11:29

Client ID: JM-S-73

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.4026	J	ug/l	1.000	0.3430	1	03/13/22 02:48	03/14/22 19:59	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-145

Date Collected: 03/05/22 11:31

Client ID: JM-S-74

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	7.044		ug/l	1.000	0.3430	1	03/13/22 02:48	03/14/22 20:04	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-147

Date Collected: 03/05/22 11:35

Client ID: JM-WF-75

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		ug/l	1.000	0.3430	1	03/13/22 02:48	03/14/22 20:09	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-149

Date Collected: 03/05/22 11:37

Client ID: JM-WF-76

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		ug/l	1.000	0.3430	1	03/13/22 02:48	03/14/22 20:14	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-151

Date Collected: 03/05/22 11:39

Client ID: JM-1M-77

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		ug/l	1.000	0.3430	1	03/13/22 02:48	03/14/22 20:20	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-153

Date Collected: 03/05/22 11:41

Client ID: JM-S-78

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	117.6		ug/l	1.000	0.3430	1	03/13/22 02:48	03/14/22 20:25	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-154

Date Collected: 03/05/22 11:42

Client ID: JM-S-78-F

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	6.968		ug/l	1.000	0.3430	1	03/16/22 07:46	03/16/22 23:29	EPA 3005A	3,200.8	WP



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-155

Date Collected: 03/05/22 11:43

Client ID: JM-WF-79

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	1.867		ug/l	1.000	0.3430	1	03/13/22 02:48	03/14/22 20:41	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-157

Date Collected: 03/05/22 11:52

Client ID: JM-1M-80

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.7261	J	ug/l	1.000	0.3430	1	03/13/22 02:48	03/14/22 20:46	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-159

Date Collected: 03/05/22 11:54

Client ID: JM-S-81

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	178.6		ug/l	1.000	0.3430	1	03/13/22 02:48	03/14/22 20:51	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-160

Date Collected: 03/05/22 11:55

Client ID: JM-S-81-F

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.4370	J	ug/l	1.000	0.3430	1	03/16/22 07:46	03/16/22 23:32	EPA 3005A	3,200.8	WP



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22**SAMPLE RESULTS**

Lab ID: L2211733-161

Date Collected: 03/05/22 12:02

Client ID: JM-WF-82

Date Received: 03/07/22

Sample Location: JACKSON

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	11.67		ug/l	1.000	0.3430	1	03/13/22 02:48	03/14/22 20:56	EPA 3005A	3,200.8	4



Project Name: JACKSON LDW-MEMORIAL H.S

Lab Number: L2211733

Project Number: Not Specified

Report Date: 03/28/22

Method Blank Analysis Batch Quality Control

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 01 Batch: WG1612739-1										
Lead, Total	ND		ug/l	1.000	0.3430	1	03/09/22 09:14	03/09/22 18:01	3,200.8	CD

Prep Information

Digestion Method: EPA 3005A

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 03,05,07,09,11,13,15,17,19,21,23,25,27,29,31,33,35,37,39,41 Batch: WG1613414-1										
Lead, Total	ND		ug/l	1.000	0.3430	1	03/11/22 10:04	03/13/22 22:10	3,200.8	WP

Prep Information

Digestion Method: EPA 3005A

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 43,45,47,49,51,53,55,57,59,61,63,65,67,69,71,73,75,77,79,81 Batch: WG1613415-1										
Lead, Total	ND		ug/l	1.000	0.3430	1	03/11/22 10:28	03/14/22 10:25	3,200.8	SV

Prep Information

Digestion Method: EPA 3005A

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 83,85,87,89,91,93,95,97,99,101,103,105,107,109,111,113,115,117,119,121 Batch: WG1613416-1										
Lead, Total	ND		ug/l	1.000	0.3430	1	03/11/22 10:40	03/14/22 15:22	3,200.8	4

Project Name: JACKSON LDW-MEMORIAL H.S
Project Number: Not Specified

Lab Number: L2211733
Report Date: 03/28/22

Method Blank Analysis Batch Quality Control

Prep Information

Digestion Method: EPA 3005A

Parameter	Result Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 123,125,127,129,131,133,135,137,139,141,143,145,147,149,151,153,155,157,159,161 Batch: WG1613417-1									
Lead, Total	ND	ug/l	1.000	0.3430	1	03/13/22 02:48	03/14/22 18:32	3,200.8	4

Prep Information

Digestion Method: EPA 3005A

Parameter	Result Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Analytical Method	Analyst
Total Metals - Mansfield Lab for sample(s): 100,102,114,116,154,160 Batch: WG1615311-1									
Lead, Total	ND	ug/l	1.000	0.3430	1	03/16/22 07:46	03/16/22 21:27	3,200.8	WP

Prep Information

Digestion Method: EPA 3005A

Lab Control Sample Analysis

Batch Quality Control

Project Name: JACKSON LDW-MEMORIAL H.S

Lab Number: L2211733

Project Number: Not Specified

Report Date: 03/28/22

Parameter	LCS		LCSD		%Recovery		RPD Limits	
	%Recovery	Qual	%Recovery	Qual	RPD	Qual	RPD Limits	
Total Metals - Mansfield Lab Associated sample(s): 01 Batch: WG1612739-2								
Lead, Total	95		-		85-115		-	
Total Metals - Mansfield Lab Associated sample(s): 03,05,07,09,11,13,15,17,19,21,23,25,27,29,31,33,35,37,39,41 Batch: WG1613414-2								
Lead, Total	89		-		85-115		-	
Total Metals - Mansfield Lab Associated sample(s): 43,45,47,49,51,53,55,57,59,61,63,65,67,69,71,73,75,77,79,81 Batch: WG1613415-2								
Lead, Total	93		-		85-115		-	
Total Metals - Mansfield Lab Associated sample(s): 83,85,87,89,91,93,95,97,99,101,103,105,107,109,111,113,115,117,119,121 Batch: WG1613416-2								
Lead, Total	92		-		85-115		-	
Total Metals - Mansfield Lab Associated sample(s): 123,125,127,129,131,133,135,137,139,141,143,145,147,149,151,153,155,157,159,161 Batch: WG1613417-2								
Lead, Total	95		-		85-115		-	
Total Metals - Mansfield Lab Associated sample(s): 100,102,114,116,154,160 Batch: WG1615311-2								
Lead, Total	110		-		85-115		-	

Matrix Spike Analysis
Batch Quality Control

Project Name: JACKSON LDW-MEMORIAL H.S
Project Number: Not Specified

Lab Number: L2211733
Report Date: 03/28/22

Parameter	Native Sample	MS Added	MS Found	MS %Recovery	MSD Found	MSD %Recovery	Recovery Qual	Recovery Limits	RPD Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 03,05,07,09,11,13,15,17,19,21,23,25,27,29,31,33,35,37,39,41 QC Batch ID: WG1613414-3 QC Sample: L2211733-03 Client ID: JM-WF-01										
Lead, Total	0.7039J	530	456.9	86	-	-	-	70-130	-	20
Total Metals - Mansfield Lab Associated sample(s): 03,05,07,09,11,13,15,17,19,21,23,25,27,29,31,33,35,37,39,41 QC Batch ID: WG1613414-5 QC Sample: L2211733-05 Client ID: JM-WF-02										
Lead, Total	ND	530	471.7	89	-	-	-	70-130	-	20
Total Metals - Mansfield Lab Associated sample(s): 43,45,47,49,51,53,55,57,59,61,63,65,67,69,71,73,75,77,79,81 QC Batch ID: WG1613415-3 QC Sample: L2211733-43 Client ID: JM-BF-23										
Lead, Total	ND	530	466.8	88	-	-	-	70-130	-	20
Total Metals - Mansfield Lab Associated sample(s): 43,45,47,49,51,53,55,57,59,61,63,65,67,69,71,73,75,77,79,81 QC Batch ID: WG1613415-5 QC Sample: L2211733-45 Client ID: JM-S-24										
Lead, Total	0.4567J	530	467.2	88	-	-	-	70-130	-	20
Total Metals - Mansfield Lab Associated sample(s): 83,85,87,89,91,93,95,97,99,101,103,105,107,109,111,113,115,117,119,121 QC Batch ID: WG1613416-3 QC Sample: L2211733-83 Client ID: JM-WF-43										
Lead, Total	2.251	530	455.4	85	-	-	-	70-130	-	20
Total Metals - Mansfield Lab Associated sample(s): 83,85,87,89,91,93,95,97,99,101,103,105,107,109,111,113,115,117,119,121 QC Batch ID: WG1613416-5 QC Sample: L2211733-85 Client ID: JM-WF-44										
Lead, Total	3.477	530	474.9	89	-	-	-	70-130	-	20
Total Metals - Mansfield Lab Associated sample(s): 123,125,127,129,131,133,135,137,139,141,143,145,147,149,151,153,155,157,159,161 QC Batch ID: WG1613417-3 QC Sample: L2211733-123 Client ID: JM-S-63										
Lead, Total	0.5335J	530	472.5	89	-	-	-	70-130	-	20
Total Metals - Mansfield Lab Associated sample(s): 123,125,127,129,131,133,135,137,139,141,143,145,147,149,151,153,155,157,159,161 QC Batch ID: WG1613417-5 QC Sample: L2211733-125 Client ID: JM-WF-64										
Lead, Total	3.218	530	473.2	89	-	-	-	70-130	-	20



Lab Duplicate Analysis

Batch Quality Control

Project Name: JACKSON LDW-MEMORIAL H.S

Lab Number: L2211733

Project Number: Not Specified

Report Date: 03/28/22

Parameter	Native Sample	Duplicate Sample	Units	RPD	Qual	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 03,05,07,09,11,13,15,17,19,21,23,25,27,29,31,33,35,37,39,41 L2211733-03 Client ID: JM-WF-01	QC Batch ID: WG1613414-4 QC Sample:					
Lead, Total	0.7039J	0.6976J	ug/l	NC		20
Total Metals - Mansfield Lab Associated sample(s): 03,05,07,09,11,13,15,17,19,21,23,25,27,29,31,33,35,37,39,41 L2211733-05 Client ID: JM-WF-02	QC Batch ID: WG1613414-6 QC Sample:					
Lead, Total	ND	ND	ug/l	NC		20
Total Metals - Mansfield Lab Associated sample(s): 43,45,47,49,51,53,55,57,59,61,63,65,67,69,71,73,75,77,79,81 L2211733-43 Client ID: JM-BF-23	QC Batch ID: WG1613415-4 QC Sample:					
Lead, Total	ND	ND	ug/l	NC		20
Total Metals - Mansfield Lab Associated sample(s): 43,45,47,49,51,53,55,57,59,61,63,65,67,69,71,73,75,77,79,81 L2211733-45 Client ID: JM-S-24	QC Batch ID: WG1613415-6 QC Sample:					
Lead, Total	0.4567J	0.4817J	ug/l	NC		20
Total Metals - Mansfield Lab Associated sample(s): 83,85,87,89,91,93,95,97,99,101,103,105,107,109,111,113,115,117,119,121 QC Sample: L2211733-83 Client ID: JM-WF-43	QC Batch ID: WG1613416-4					
Lead, Total	2.251	2.279	ug/l	1		20
Total Metals - Mansfield Lab Associated sample(s): 83,85,87,89,91,93,95,97,99,101,103,105,107,109,111,113,115,117,119,121 QC Sample: L2211733-85 Client ID: JM-WF-44	QC Batch ID: WG1613416-6					
Lead, Total	3.477	3.512	ug/l	1		20
Total Metals - Mansfield Lab Associated sample(s): 123,125,127,129,131,133,135,137,139,141,143,145,147,149,151,153,155,157,159,161 WG1613417-4 QC Sample: L2211733-123 Client ID: JM-S-63	QC Batch ID:					
Lead, Total	0.5335J	0.5683J	ug/l	NC		20

Lab Duplicate Analysis
Batch Quality Control

Project Name: JACKSON LDW-MEMORIAL H.S
Project Number: Not Specified

Lab Number: L2211733
Report Date: 03/28/22

Parameter	Native Sample	Duplicate Sample	Units	RPD	RPD Limits
Total Metals - Mansfield Lab Associated sample(s): 123,125,127,129,131,133,135,137,139,141,143,145,147,149,151,153,155,157,159,161 QC Batch ID: WG1613417-6 QC Sample: L2211733-125 Client ID: JM-WF-64					
Lead, Total	3.218	3.187	ug/l	1	20



Sample Receipt and Container Information

Were project specific reporting limits specified? NO

Cooler Information

Cooler	Custody Seal
B	Absent
C	Absent
E	Absent
G	Absent
I	Absent
K	Absent

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2211733-01A	Plastic 250ml HNO3 preserved	C	<2	<2	5.3	Y	Absent		PB-2008T-PPB(180)
L2211733-02A	Plastic 250ml HNO3 preserved	C	<2	<2	5.3	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-03A	Plastic 250ml HNO3 preserved	C	<2	<2	5.3	Y	Absent		PB-2008T-PPB(180)
L2211733-04A	Plastic 250ml HNO3 preserved	C	<2	<2	5.3	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-05A	Plastic 250ml HNO3 preserved	C	<2	<2	5.3	Y	Absent		PB-2008T-PPB(180)
L2211733-06A	Plastic 250ml HNO3 preserved	C	<2	<2	5.3	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-07A	Plastic 250ml HNO3 preserved	C	<2	<2	5.3	Y	Absent		PB-2008T-PPB(180)
L2211733-08A	Plastic 250ml HNO3 preserved	C	<2	<2	5.3	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-09A	Plastic 250ml HNO3 preserved	C	<2	<2	5.3	Y	Absent		PB-2008T-PPB(180)
L2211733-100A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		PB-2008T-PPB(180)
L2211733-101A	Plastic 250ml HNO3 preserved	G	<2	<2	2.2	Y	Absent		PB-2008T-PPB(180)
L2211733-102A	Plastic 250ml HNO3 preserved	E	<2	<2	3.6	Y	Absent		PB-2008T-PPB(180)
L2211733-103A	Plastic 250ml HNO3 preserved	G	<2	<2	2.2	Y	Absent		PB-2008T-PPB(180)
L2211733-104A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-105A	Plastic 250ml HNO3 preserved	G	<2	<2	2.2	Y	Absent		PB-2008T-PPB(180)
L2211733-106A	Plastic 250ml HNO3 preserved	E	<2	<2	3.6	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-107A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		PB-2008T-PPB(180)

*Values in parentheses indicate holding time in days



Container Information			Initial		Final		Temp		Frozen		Analysis(*)
Container ID	Container Type	Cooler	pH	pH	pH	deg C	Pres	Seal	Date/Time		
L2211733-108A	Plastic 250ml HNO3 preserved	I	<2	<2	<2	3.9	Y	Absent		HOLD-METAL-TOTAL(180)	
L2211733-109A	Plastic 250ml HNO3 preserved	G	<2	<2	<2	2.2	Y	Absent		PB-2008T-PPB(180)	
L2211733-10A	Plastic 250ml HNO3 preserved	C	<2	<2	<2	5.3	Y	Absent		HOLD-METAL-TOTAL(180)	
L2211733-110A	Plastic 250ml HNO3 preserved	I	<2	<2	<2	3.9	Y	Absent		HOLD-METAL-TOTAL(180)	
L2211733-111A	Plastic 250ml HNO3 preserved	E	<2	<2	<2	3.6	Y	Absent		PB-2008T-PPB(180)	
L2211733-112A	Plastic 250ml HNO3 preserved	G	<2	<2	<2	2.2	Y	Absent		HOLD-METAL-TOTAL(180)	
L2211733-113A	Plastic 250ml HNO3 preserved	G	<2	<2	<2	2.2	Y	Absent		PB-2008T-PPB(180)	
L2211733-114A	Plastic 250ml HNO3 preserved	G	<2	<2	<2	2.2	Y	Absent		PB-2008T-PPB(180)	
L2211733-115A	Plastic 250ml HNO3 preserved	G	<2	<2	<2	2.2	Y	Absent		PB-2008T-PPB(180)	
L2211733-116A	Plastic 250ml HNO3 preserved	G	<2	<2	<2	2.2	Y	Absent		PB-2008T-PPB(180)	
L2211733-117A	Plastic 250ml HNO3 preserved	E	<2	<2	<2	3.6	Y	Absent		PB-2008T-PPB(180)	
L2211733-118A	Plastic 250ml HNO3 preserved	G	<2	<2	<2	2.2	Y	Absent		HOLD-METAL-TOTAL(180)	
L2211733-119A	Plastic 250ml HNO3 preserved	G	<2	<2	<2	2.2	Y	Absent		PB-2008T-PPB(180)	
L2211733-11A	Plastic 250ml HNO3 preserved	C	<2	<2	<2	5.3	Y	Absent		PB-2008T-PPB(180)	
L2211733-120A	Plastic 250ml HNO3 preserved	G	<2	<2	<2	2.2	Y	Absent		HOLD-METAL-TOTAL(180)	
L2211733-121A	Plastic 250ml HNO3 preserved	I	<2	<2	<2	3.9	Y	Absent		PB-2008T-PPB(180)	
L2211733-122A	Plastic 250ml HNO3 preserved	K	<2	<2	<2	3.7	Y	Absent		HOLD-METAL-TOTAL(180)	
L2211733-123A	Plastic 250ml HNO3 preserved	G	<2	<2	<2	2.2	Y	Absent		PB-2008T-PPB(180)	
L2211733-124A	Plastic 250ml HNO3 preserved	I	<2	<2	<2	3.9	Y	Absent		HOLD-METAL-TOTAL(180)	
L2211733-125A	Plastic 250ml HNO3 preserved	E	<2	<2	<2	3.6	Y	Absent		PB-2008T-PPB(180)	
L2211733-126A	Plastic 250ml HNO3 preserved	I	<2	<2	<2	3.9	Y	Absent		HOLD-METAL-TOTAL(180)	
L2211733-127A	Plastic 250ml HNO3 preserved	E	<2	<2	<2	3.6	Y	Absent		PB-2008T-PPB(180)	
L2211733-128A	Plastic 250ml HNO3 preserved	G	<2	<2	<2	2.2	Y	Absent		HOLD-METAL-TOTAL(180)	
L2211733-129A	Plastic 250ml HNO3 preserved	G	<2	<2	<2	2.2	Y	Absent		PB-2008T-PPB(180)	
L2211733-12A	Plastic 250ml HNO3 preserved	C	<2	<2	<2	5.3	Y	Absent		HOLD-METAL-TOTAL(180)	
L2211733-130A	Plastic 250ml HNO3 preserved	G	<2	<2	<2	2.2	Y	Absent		HOLD-METAL-TOTAL(180)	
L2211733-131A	Plastic 250ml HNO3 preserved	K	<2	<2	<2	3.7	Y	Absent		PB-2008T-PPB(180)	
L2211733-132A	Plastic 250ml HNO3 preserved	G	<2	<2	<2	2.2	Y	Absent		HOLD-METAL-TOTAL(180)	

Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2211733-133A	Plastic 250ml HNO3 preserved	G	<2	<2	2.2	Y	Absent		PB-2008T-PPB(180)
L2211733-134A	Plastic 250ml HNO3 preserved	K	<2	<2	3.7	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-135A	Plastic 250ml HNO3 preserved	G	<2	<2	2.2	Y	Absent		PB-2008T-PPB(180)
L2211733-136A	Plastic 250ml HNO3 preserved	G	<2	<2	2.2	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-137A	Plastic 250ml HNO3 preserved	G	<2	<2	2.2	Y	Absent		PB-2008T-PPB(180)
L2211733-138A	Plastic 250ml HNO3 preserved	G	<2	<2	2.2	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-139A	Plastic 250ml HNO3 preserved	G	<2	<2	2.2	Y	Absent		PB-2008T-PPB(180)
L2211733-13A	Plastic 250ml HNO3 preserved	C	<2	<2	5.3	Y	Absent		PB-2008T-PPB(180)
L2211733-140A	Plastic 250ml HNO3 preserved	G	<2	<2	2.2	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-141A	Plastic 250ml HNO3 preserved	G	<2	<2	2.2	Y	Absent		PB-2008T-PPB(180)
L2211733-142A	Plastic 250ml HNO3 preserved	G	<2	<2	2.2	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-143A	Plastic 250ml HNO3 preserved	G	<2	<2	2.2	Y	Absent		PB-2008T-PPB(180)
L2211733-144A	Plastic 250ml HNO3 preserved	G	<2	<2	2.2	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-145A	Plastic 250ml HNO3 preserved	G	<2	<2	2.2	Y	Absent		PB-2008T-PPB(180)
L2211733-146A	Plastic 250ml HNO3 preserved	G	<2	<2	2.2	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-147A	Plastic 250ml HNO3 preserved	G	<2	<2	2.2	Y	Absent		PB-2008T-PPB(180)
L2211733-148A	Plastic 250ml HNO3 preserved	G	<2	<2	2.2	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-149A	Plastic 250ml HNO3 preserved	G	<2	<2	2.2	Y	Absent		PB-2008T-PPB(180)
L2211733-14A	Plastic 250ml HNO3 preserved	C	<2	<2	5.3	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-150A	Plastic 250ml HNO3 preserved	G	<2	<2	2.2	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-151A	Plastic 250ml HNO3 preserved	G	<2	<2	2.2	Y	Absent		PB-2008T-PPB(180)
L2211733-152A	Plastic 250ml HNO3 preserved	G	<2	<2	2.2	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-153A	Plastic 250ml HNO3 preserved	G	<2	<2	2.2	Y	Absent		PB-2008T-PPB(180)
L2211733-154A	Plastic 250ml HNO3 preserved	G	<2	<2	2.2	Y	Absent		PB-2008T-PPB(180)
L2211733-155A	Plastic 250ml HNO3 preserved	G	<2	<2	2.2	Y	Absent		PB-2008T-PPB(180)
L2211733-156A	Plastic 250ml HNO3 preserved	G	<2	<2	2.2	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-157A	Plastic 250ml HNO3 preserved	K	<2	<2	3.7	Y	Absent		PB-2008T-PPB(180)
L2211733-158A	Plastic 250ml HNO3 preserved	K	<2	<2	3.7	Y	Absent		HOLD-METAL-TOTAL(180)

Container Information			Cooler		Initial	Final	Temp	Frozen		Analysis(*)
Container ID	Container Type		pH	pH	pH	deg	C	Pres	Date/Time	
L2211733-159A	Plastic 250ml HNO3 preserved		K	<2	<2	3.7	Y	Absent		PB-2008T-PPB(180)
L2211733-15A	Plastic 250ml HNO3 preserved		C	<2	<2	5.3	Y	Absent		PB-2008T-PPB(180)
L2211733-160A	Plastic 250ml HNO3 preserved		K	<2	<2	3.7	Y	Absent		PB-2008T-PPB(180)
L2211733-161A	Plastic 250ml HNO3 preserved		K	<2	<2	3.7	Y	Absent		PB-2008T-PPB(180)
L2211733-162A	Plastic 250ml HNO3 preserved		K	<2	<2	3.7	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-16A	Plastic 250ml HNO3 preserved		C	<2	<2	5.3	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-17A	Plastic 250ml HNO3 preserved		C	<2	<2	5.3	Y	Absent		PB-2008T-PPB(180)
L2211733-18A	Plastic 250ml HNO3 preserved		C	<2	<2	5.3	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-19A	Plastic 250ml HNO3 preserved		C	<2	<2	5.3	Y	Absent		PB-2008T-PPB(180)
L2211733-20A	Plastic 250ml HNO3 preserved		C	<2	<2	5.3	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-21A	Plastic 250ml HNO3 preserved		C	<2	<2	5.3	Y	Absent		PB-2008T-PPB(180)
L2211733-22A	Plastic 250ml HNO3 preserved		C	<2	<2	5.3	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-23A	Plastic 250ml HNO3 preserved		C	<2	<2	5.3	Y	Absent		PB-2008T-PPB(180)
L2211733-24A	Plastic 250ml HNO3 preserved		C	<2	<2	5.3	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-25A	Plastic 250ml HNO3 preserved		C	<2	<2	5.3	Y	Absent		PB-2008T-PPB(180)
L2211733-26A	Plastic 250ml HNO3 preserved		C	<2	<2	5.3	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-27A	Plastic 250ml HNO3 preserved		C	<2	<2	5.3	Y	Absent		PB-2008T-PPB(180)
L2211733-28A	Plastic 250ml HNO3 preserved		C	<2	<2	5.3	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-29A	Plastic 250ml HNO3 preserved		C	<2	<2	5.3	Y	Absent		PB-2008T-PPB(180)
L2211733-30A	Plastic 250ml HNO3 preserved		C	<2	<2	5.3	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-31A	Plastic 250ml HNO3 preserved		C	<2	<2	5.3	Y	Absent		PB-2008T-PPB(180)
L2211733-32A	Plastic 250ml HNO3 preserved		C	<2	<2	5.3	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-33A	Plastic 250ml HNO3 preserved		C	<2	<2	5.3	Y	Absent		PB-2008T-PPB(180)
L2211733-34A	Plastic 250ml HNO3 preserved		C	<2	<2	5.3	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-35A	Plastic 250ml HNO3 preserved		C	<2	<2	5.3	Y	Absent		PB-2008T-PPB(180)
L2211733-36A	Plastic 250ml HNO3 preserved		C	<2	<2	5.3	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-37A	Plastic 250ml HNO3 preserved		C	<2	<2	5.3	Y	Absent		PB-2008T-PPB(180)
L2211733-38A	Plastic 250ml HNO3 preserved		C	<2	<2	5.3	Y	Absent		HOLD-METAL-TOTAL(180)

*Values in parentheses indicate holding time in days



Container Information			Cooler		Initial	Final	Temp	Frozen		Analysis(*)
Container ID	Container Type		pH	pH	pH	deg	C	Pres	Date/Time	
L2211733-39A	Plastic 250ml HNO3 preserved		C	<2	<2	5.3	Y	Absent		PB-2008T-PPB(180)
L2211733-40A	Plastic 250ml HNO3 preserved		C	<2	<2	5.3	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-41A	Plastic 250ml HNO3 preserved		B	<2	<2	2.2	Y	Absent		PB-2008T-PPB(180)
L2211733-42A	Plastic 250ml HNO3 preserved		B	<2	<2	2.2	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-43A	Plastic 250ml HNO3 preserved		B	<2	<2	2.2	Y	Absent		PB-2008T-PPB(180)
L2211733-44A	Plastic 250ml HNO3 preserved		E	<2	<2	3.6	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-45A	Plastic 250ml HNO3 preserved		B	<2	<2	2.2	Y	Absent		PB-2008T-PPB(180)
L2211733-46A	Plastic 250ml HNO3 preserved		B	<2	<2	2.2	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-47A	Plastic 250ml HNO3 preserved		B	<2	<2	2.2	Y	Absent		PB-2008T-PPB(180)
L2211733-48A	Plastic 250ml HNO3 preserved		B	<2	<2	2.2	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-49A	Plastic 250ml HNO3 preserved		E	<2	<2	3.6	Y	Absent		PB-2008T-PPB(180)
L2211733-50A	Plastic 250ml HNO3 preserved		E	<2	<2	3.6	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-51A	Plastic 250ml HNO3 preserved		E	<2	<2	3.6	Y	Absent		PB-2008T-PPB(180)
L2211733-52A	Plastic 250ml HNO3 preserved		E	<2	<2	3.6	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-53A	Plastic 250ml HNO3 preserved		E	<2	<2	3.6	Y	Absent		PB-2008T-PPB(180)
L2211733-54A	Plastic 250ml HNO3 preserved		E	<2	<2	3.6	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-55A	Plastic 250ml HNO3 preserved		E	<2	<2	3.6	Y	Absent		PB-2008T-PPB(180)
L2211733-56A	Plastic 250ml HNO3 preserved		E	<2	<2	3.6	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-57A	Plastic 250ml HNO3 preserved		E	<2	<2	3.6	Y	Absent		PB-2008T-PPB(180)
L2211733-58A	Plastic 250ml HNO3 preserved		E	<2	<2	3.6	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-59A	Plastic 250ml HNO3 preserved		E	<2	<2	3.6	Y	Absent		PB-2008T-PPB(180)
L2211733-60A	Plastic 250ml HNO3 preserved		E	<2	<2	3.6	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-61A	Plastic 250ml HNO3 preserved		B	<2	<2	2.2	Y	Absent		PB-2008T-PPB(180)
L2211733-62A	Plastic 250ml HNO3 preserved		B	<2	<2	2.2	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-63A	Plastic 250ml HNO3 preserved		B	<2	<2	2.2	Y	Absent		PB-2008T-PPB(180)
L2211733-64A	Plastic 250ml HNO3 preserved		B	<2	<2	2.2	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-65A	Plastic 250ml HNO3 preserved		E	<2	<2	3.6	Y	Absent		PB-2008T-PPB(180)
L2211733-66A	Plastic 250ml HNO3 preserved		B	<2	<2	2.2	Y	Absent		HOLD-METAL-TOTAL(180)

*Values in parentheses indicate holding time in days



Container Information

Container ID	Container Type	Cooler	Initial pH	Final pH	Temp deg C	Pres	Seal	Frozen Date/Time	Analysis(*)
L2211733-67A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		PB-2008T-PPB(180)
L2211733-68A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-69A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		PB-2008T-PPB(180)
L2211733-70A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-71A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		PB-2008T-PPB(180)
L2211733-72A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-73A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		PB-2008T-PPB(180)
L2211733-74A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-75A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		PB-2008T-PPB(180)
L2211733-76A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-77A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		PB-2008T-PPB(180)
L2211733-78A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-79A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		PB-2008T-PPB(180)
L2211733-80A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-81A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		PB-2008T-PPB(180)
L2211733-82A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-83A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		PB-2008T-PPB(180)
L2211733-84A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-85A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		PB-2008T-PPB(180)
L2211733-86A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-87A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		PB-2008T-PPB(180)
L2211733-88A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-89A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		PB-2008T-PPB(180)
L2211733-90A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-91A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		PB-2008T-PPB(180)
L2211733-92A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		HOLD-METAL-TOTAL(180)
L2211733-93A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		PB-2008T-PPB(180)
L2211733-94A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		HOLD-METAL-TOTAL(180)



Container Information			Initial		Final		Temp		Frozen		Analysis(*)
Container ID	Container Type	Cooler	pH	pH	deg C	Pres	Seal	Date/Time			
L2211733-95A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		PB-2008T-PPB(180)		
L2211733-96A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		HOLD-METAL-TOTAL(180)		
L2211733-97A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		PB-2008T-PPB(180)		
L2211733-98A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		HOLD-METAL-TOTAL(180)		
L2211733-99A	Plastic 250ml HNO3 preserved	I	<2	<2	3.9	Y	Absent		PB-2008T-PPB(180)		

*Values in parentheses indicate holding time in days



Project Name: JACKSON LDW-MEMORIAL H.S**Lab Number:** L2211733**Project Number:** Not Specified**Report Date:** 03/28/22

GLOSSARY

Acronyms

DL	- Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the limit of quantitation (LOQ). The DL includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)
EDL	- Estimated Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the reporting limit (RL). The EDL includes any adjustments from dilutions, concentrations or moisture content, where applicable. The use of EDLs is specific to the analysis of PAHs using Solid-Phase Microextraction (SPME).
EMPC	- Estimated Maximum Possible Concentration: The concentration that results from the signal present at the retention time of an analyte when the ions meet all of the identification criteria except the ion abundance ratio criteria. An EMPC is a worst-case estimate of the concentration.
EPA	- Environmental Protection Agency.
LCS	- Laboratory Control Sample: A sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes or a material containing known and verified amounts of analytes.
LCSD	- Laboratory Control Sample Duplicate: Refer to LCS.
LFB	- Laboratory Fortified Blank: A sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes or a material containing known and verified amounts of analytes.
LOD	- Limit of Detection: This value represents the level to which a target analyte can reliably be detected for a specific analyte in a specific matrix by a specific method. The LOD includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)
LOQ	- Limit of Quantitation: The value at which an instrument can accurately measure an analyte at a specific concentration. The LOQ includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.) Limit of Quantitation: The value at which an instrument can accurately measure an analyte at a specific concentration. The LOQ includes any adjustments from dilutions, concentrations or moisture content, where applicable. (DoD report formats only.)
MDL	- Method Detection Limit: This value represents the level to which target analyte concentrations are reported as estimated values, when those target analyte concentrations are quantified below the reporting limit (RL). The MDL includes any adjustments from dilutions, concentrations or moisture content, where applicable.
MS	- Matrix Spike Sample: A sample prepared by adding a known mass of target analyte to a specified amount of matrix sample for which an independent estimate of target analyte concentration is available. For Method 332.0, the spike recovery is calculated using the native concentration, including estimated values.
MSD	- Matrix Spike Sample Duplicate: Refer to MS.
NA	- Not Applicable.
NC	- Not Calculated: Term is utilized when one or more of the results utilized in the calculation are non-detect at the parameter's reporting unit.
NDPA/DPA	- N-Nitrosodiphenylamine/Diphenylamine.
NI	- Not Ignitable.
NP	- Non-Plastic: Term is utilized for the analysis of Atterberg Limits in soil.
NR	- No Results: Term is utilized when 'No Target Compounds Requested' is reported for the analysis of Volatile or Semivolatile Organic TIC only requests.
RL	- Reporting Limit: The value at which an instrument can accurately measure an analyte at a specific concentration. The RL includes any adjustments from dilutions, concentrations or moisture content, where applicable.
RPD	- Relative Percent Difference: The results from matrix and/or matrix spike duplicates are primarily designed to assess the precision of analytical results in a given matrix and are expressed as relative percent difference (RPD). Values which are less than five times the reporting limit for any individual parameter are evaluated by utilizing the absolute difference between the values; although the RPD value will be provided in the report.
SRM	- Standard Reference Material: A reference sample of a known or certified value that is of the same or similar matrix as the associated field samples.
STLP	- Semi-dynamic Tank Leaching Procedure per EPA Method 1315.
TEF	- Toxic Equivalency Factors: The values assigned to each dioxin and furan to evaluate their toxicity relative to 2,3,7,8-TCDD.
TEQ	- Toxic Equivalent: The measure of a sample's toxicity derived by multiplying each dioxin and furan by its corresponding TEF and then summing the resulting values.
TIC	- Tentatively Identified Compound: A compound that has been identified to be present and is not part of the target compound list (TCL) for the method and/or program. All TICs are qualitatively identified and reported as estimated concentrations.

Report Format: DU Report with 'J' Qualifiers

Project Name: JACKSON LDW-MEMORIAL H.S
Project Number: Not Specified

Lab Number: L2211733
Report Date: 03/28/22

Footnotes

- 1 - The reference for this analyte should be considered modified since this analyte is absent from the target analyte list of the original method.

Terms

Analytical Method: Both the document from which the method originates and the analytical reference method. (Example: EPA 8260B is shown as 1,8260B.) The codes for the reference method documents are provided in the References section of the Addendum.

Difference: With respect to Total Oxidizable Precursor (TOP) Assay analysis, the difference is defined as the Post-Treatment value minus the Pre-Treatment value.

Final pH: As it pertains to Sample Receipt & Container Information section of the report, Final pH reflects pH of container determined after adjustment at the laboratory, if applicable. If no adjustment required, value reflects Initial pH.

Frozen Date/Time: With respect to Volatile Organics in soil, Frozen Date/Time reflects the date/time at which associated Reagent Water-preserved vials were initially frozen. Note: If frozen date/time is beyond 48 hours from sample collection, value will be reflected in 'bold'.

Initial pH: As it pertains to Sample Receipt & Container Information section of the report, Initial pH reflects pH of container determined upon receipt, if applicable.

PAH Total: With respect to Alkylated PAH analyses, the 'PAHs, Total' result is defined as the summation of results for all or a subset of the following compounds: Naphthalene, C1-C4 Naphthalenes, 2-Methylnaphthalene, 1-Methylnaphthalene, Biphenyl, Acenaphthylene, Acenaphthene, Fluorene, C1-C3 Fluorenes, Phenanthrene, C1-C4 Phenanthrenes/Anthracenes, Anthracene, Fluoranthene, Pyrene, C1-C4 Fluoranthenes/Pyrenes, Benz(a)anthracene, Chrysene, C1-C4 Chrysenes, Benzo(b)fluoranthene, Benzo(j)+(k)fluoranthene, Benzo(e)pyrene, Benzo(a)pyrene, Perylene, Indeno(1,2,3-cd)pyrene, Dibenz(ah)+(ac)anthracene, Benzo(g,h,i)perylene. If a 'Total' result is requested, the results of its individual components will also be reported.

PFAS Total: With respect to PFAS analyses, the 'PFAS, Total (5)' result is defined as the summation of results for: PFHpA, PFHxS, PFOA, PFNA and PFOS. In addition, the 'PFAS, Total (6)' result is defined as the summation of results for: PFHpA, PFHxS, PFOA, PFNA, PFDA and PFOS. For MassDEP DW compliance analysis only, the 'PFAS, Total (6)' result is defined as the summation of results at or above the RL. Note: If a 'Total' result is requested, the results of its individual components will also be reported.

The target compound Chlordane (CAS No. 57-74-9) is reported for GC ECD analyses. Per EPA, this compound "refers to a mixture of chlordane isomers, other chlorinated hydrocarbons and numerous other components." (Reference: USEPA Toxicological Review of Chlordane, In Support of Summary Information on the Integrated Risk Information System (IRIS), December 1997.)

Total: With respect to Organic analyses, a 'Total' result is defined as the summation of results for individual isomers or Aroclors. If a 'Total' result is requested, the results of its individual components will also be reported. This is applicable to 'Total' results for methods 8260, 8081 and 8082.

Data Qualifiers

- A** - Spectra identified as "Aldol Condensates" are byproducts of the extraction/concentration procedures when acetone is introduced in the process.
- B** - The analyte was detected above the reporting limit in the associated method blank. Flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank. For MCP-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank. For DOD-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte at less than ten times (10x) the concentration found in the blank AND the analyte was detected above one-half the reporting limit (or above the reporting limit for common lab contaminants) in the associated method blank. For NJ-Air-related projects, flag only applies to associated field samples that have detectable concentrations of the analyte above the reporting limit. For NJ-related projects (excluding Air), flag only applies to associated field samples that have detectable concentrations of the analyte, which was detected above the reporting limit in the associated method blank or above five times the reporting limit for common lab contaminants (Phthalates, Acetone, Methylene Chloride, 2-Butanone).
- C** - Co-elution: The target analyte co-elutes with a known lab standard (i.e. surrogate, internal standards, etc.) for co-extracted analyses.
- D** - Concentration of analyte was quantified from diluted analysis. Flag only applies to field samples that have detectable concentrations of the analyte.
- E** - Concentration of analyte exceeds the range of the calibration curve and/or linear range of the instrument.
- F** - The ratio of quantifier ion response to qualifier ion response falls outside of the laboratory criteria. Results are considered to be an estimated maximum concentration.
- G** - The concentration may be biased high due to matrix interferences (i.e. co-elution) with non-target compound(s). The result should be considered estimated.
- H** - The analysis of pH was performed beyond the regulatory-required holding time of 15 minutes from the time of sample collection.
- I** - The lower value for the two columns has been reported due to obvious interference.
- J** - Estimated value. The Target analyte concentration is below the quantitation limit (RL), but above the Method Detection Limit (MDL) or Estimated Detection Limit (EDL) for SPME-related analyses. This represents an estimated concentration for Tentatively Identified Compounds (TICs).
- M** - Reporting Limit (RL) exceeds the MCP CAM Reporting Limit for this analyte.
- ND** - Not detected at the method detection limit (MDL) for the sample, or estimated detection limit (EDL) for SPME-related analyses.

Report Format: DU Report with 'J' Qualifiers



Project Name: JACKSON LDW-MEMORIAL H.S
Project Number: Not Specified

Lab Number: L2211733
Report Date: 03/28/22

Data Qualifiers

- NJ** - Presumptive evidence of compound. This represents an estimated concentration for Tentatively Identified Compounds (TICs), where the identification is based on a mass spectral library search.
- P** - The RPD between the results for the two columns exceeds the method-specified criteria.
- Q** - The quality control sample exceeds the associated acceptance criteria. For DOD-related projects, LCS and/or Continuing Calibration Standard exceedences are also qualified on all associated sample results. Note: This flag is not applicable for matrix spike recoveries when the sample concentration is greater than 4x the spike added or for batch duplicate RPD when the sample concentrations are less than 5x the RL. (Metals only.)
- R** - Analytical results are from sample re-analysis.
- RE** - Analytical results are from sample re-extraction.
- S** - Analytical results are from modified screening analysis.
- V** - The surrogate associated with this target analyte has a recovery outside the QC acceptance limits. (Applicable to MassDEP DW Compliance samples only.)
- Z** - The batch matrix spike and/or duplicate associated with this target analyte has a recovery/RPD outside the QC acceptance limits. (Applicable to MassDEP DW Compliance samples only.)

Report Format: DU Report with 'J' Qualifiers



Project Name: JACKSON LDW-MEMORIAL H.S
Project Number: Not Specified

Lab Number: L2211733
Report Date: 03/28/22

REFERENCES

- 3 Methods for the Determination of Metals in Environmental Samples, Supplement I. EPA/600/R-94/111. May 1994.

LIMITATION OF LIABILITIES

Alpha Analytical performs services with reasonable care and diligence normal to the analytical testing laboratory industry. In the event of an error, the sole and exclusive responsibility of Alpha Analytical shall be to re-perform the work at it's own expense. In no event shall Alpha Analytical be held liable for any incidental, consequential or special damages, including but not limited to, damages in any way connected with the use of, interpretation of, information or analysis provided by Alpha Analytical.

We strongly urge our clients to comply with EPA protocol regarding sample volume, preservation, cooling, containers, sampling procedures, holding time and splitting of samples in the field.



Certification Information

The following analytes are not included in our Primary NELAP Scope of Accreditation:

Westborough Facility

EPA 624/624.1: m/p-xylene, o-xylene, Naphthalene

EPA 625/625.1: alpha-Terpineol

EPA 8260C/8260D: NPW: 1,2,4,5-Tetramethylbenzene; 4-Ethyltoluene, Azobenzene; SCM: Iodomethane (methyl iodide), 1,2,4,5-Tetramethylbenzene; 4-Ethyltoluene.

EPA 8270D/8270E: NPW: Dimethylnaphthalene, 1,4-Diphenylhydrazine, alpha-Terpineol; SCM: Dimethylnaphthalene, 1,4-Diphenylhydrazine.

SM4500: NPW: Amenable Cyanide; SCM: Total Phosphorus, TKN, NO₂, NO₃.

Mansfield Facility

SM 2540D: TSS

EPA 8082A: NPW: PCB: 1, 5, 31, 87, 101, 110, 141, 151, 153, 180, 183, 187.

EPA TO-15: Halothane, 2,4,4-Trimethyl-2-pentene, 2,4,4-Trimethyl-1-pentene, Thiophene, 2-Methylthiophene,

3-Methylthiophene, 2-Ethylthiophene, 1,2,3-Trimethylbenzene, Indan, Indene, 1,2,4,5-Tetramethylbenzene, Benzothiophene, 1-Methylnaphthalene.

Biological Tissue Matrix: EPA 3050B

The following analytes are included in our Massachusetts DEP Scope of Accreditation

Westborough Facility:

Drinking Water

EPA 300.0: Chloride, Nitrate-N, Fluoride, Sulfate; **EPA 353.2:** Nitrate-N, Nitrite-N; **SM4500NO3-F:** Nitrate-N, Nitrite-N; **SM4500F-C, SM4500CN-CE,**

EPA 180.1, SM2130B, SM4500CI-D, SM2320B, SM2540C, SM4500H-B, SM4500NO2-B

EPA 332: Perchlorate; **EPA 524.2:** THMs and VOCs; **EPA 504.1:** EDB, DBCP.

Microbiology: **SM9215B; SM9223-P/A, SM9223B-Colilert-QT, SM9222D.**

Non-Potable Water

SM4500H,B, EPA 120.1, SM2510B, SM2540C, SM2320B, SM4500CL-E, SM4500F-BC, SM4500NH3-BH: Ammonia-N and Kjeldahl-N, **EPA 350.1:**

Ammonia-N, **LACHAT 10-107-06-1-B:** Ammonia-N, **EPA 351.1, SM4500NO3-F, EPA 353.2:** Nitrate-N, **SM4500P-E, SM4500P-B, E, SM4500SO4-E,**

SM5220D, EPA 410.4, SM5210B, SM5310C, SM4500CL-D, EPA 1664, EPA 420.1, SM4500-CN-CE, SM2540D, EPA 300: Chloride, Sulfate, Nitrate.

EPA 624.1: Volatile Halocarbons & Aromatics,

EPA 608.3: Chlordane, Toxaphene, Aldrin, alpha-BHC, beta-BHC, gamma-BHC, delta-BHC, Dieldrin, DDD, DDE, DDT, Endosulfan I, Endosulfan II, Endosulfan sulfate, Endrin, Endrin Aldehyde, Heptachlor, Heptachlor Epoxide, PCBs

EPA 625.1: SVOC (Acid/Base/Neutral Extractables), **EPA 600/4-81-045:** PCB-Oil.

Microbiology: **SM9223B-Colilert-QT; Enterolert-QT, SM9221E, EPA 1600, EPA 1603, SM9222D.**

Mansfield Facility:

Drinking Water

EPA 200.7: Al, Ba, Cd, Cr, Cu, Fe, Mn, Ni, Na, Ag, Ca, Zn. **EPA 200.8:** Al, Sb, As, Ba, Be, Cd, Cr, Cu, Pb, Mn, Ni, Se, Ag, TL, Zn. **EPA 245.1 Hg.**

EPA 522, EPA 537.1.

Non-Potable Water

EPA 200.7: Al, Sb, As, Be, Cd, Ca, Cr, Co, Cu, Fe, Pb, Mg, Mn, Mo, Ni, K, Se, Ag, Na, Sr, TL, Ti, V, Zn.

EPA 200.8: Al, Sb, As, Be, Cd, Cr, Cu, Fe, Pb, Mn, Ni, K, Se, Ag, Na, TL, Zn.

EPA 245.1 Hg.

SM2340B

For a complete listing of analytes and methods, please contact your Alpha Project Manager.

NEW JERSEY CHAIN OF CUSTODY		Service Centers Mahwah, NJ 07430: 35 Whitney Rd, Suite 5 Albany, NY 12205: 14 Walker Way Tonawanda, NY 14150: 275 Cooper Ave, Suite 105		Page 11 of 17		ALPHA Job # L22 D133	
Client Information Westborough, MA 01581 8 Walkup Dr. TEL: 508-898-9220 FAX: 508-898-9193		Project Information Project Name: Project Location: Project # (Use Project name as Project #) Project Manager: ALPHAQuote #: Turn-Around Time: Standard Rush (only if pre approved) Due Date: # of Days: Project Name: Project Location: Project # (Use Project name as Project #) Project Manager: ALPHAQuote #: Turn-Around Time: Standard Rush (only if pre approved) Due Date: # of Days:		Deliverables ☐ NJ Full / Reduced ☐ EQUIS (1 File) ☐ EQUIS (4 File) ☐ Other		Date Rec'd in Lab 3/1/22	
Client Information Client: Address: Phone: Fax: Email:		Project Information Project Name: Project Location: Project # (Use Project name as Project #) Project Manager: ALPHAQuote #: Turn-Around Time: Standard Rush (only if pre approved) Due Date: # of Days:		Regulatory Requirement ☐ SRS Residential/Non Residential ☐ SRS Impact to Groundwater ☐ NJ Ground Water Quality Standards ☐ NJ IGW SPLP Leachate Criteria ☐ Other		Billing Information ☐ Same as Client Info PO #	
Site Information Is this site impacted by Petroleum? Yes ☐ Petroleum Product:		Regulatory Requirement ☐ SRS Residential/Non Residential ☐ SRS Impact to Groundwater ☐ NJ Ground Water Quality Standards ☐ NJ IGW SPLP Leachate Criteria ☐ Other		Regulatory Requirement ☐ SRS Residential/Non Residential ☐ SRS Impact to Groundwater ☐ NJ Ground Water Quality Standards ☐ NJ IGW SPLP Leachate Criteria ☐ Other		Site Information Is this site impacted by Petroleum? Yes ☐ Petroleum Product:	
For EPH, selection is REQUIRED: ☐ Category 1 ☐ Category 2		For VOC, selection is REQUIRED: ☐ 1,4-Dioxane ☐ 8011		Other project specific requirements/comments: Please specify Metals or TAL.		Sample Filtration ☐ Done ☐ Lab to do ☐ Preservation ☐ Lab to do (Please Specify below)	
These samples have been previously analyzed by Alpha		Sample ID		Collection Date Time		Sample Matrix	
ALPHA Lab ID (Lab Use Only)		Sample ID		Collection Date Time		Sample Matrix	
11733-101		JM-WF-51		3/5/22 10:29		DW	
-102		51-F		10:30			
-103		52		10:31			
-104		52-F		10:32			
-105		53		10:33			
-106		53-F		10:34			
-107		54		10:35			
-108		54-F		10:36			
-109		55		10:37			
-110		55-F		10:38			
Preservative Code: A = None B = HCl C = HNO ₃ D = H ₂ SO ₄ E = NaOH F = MeOH G = NaHSO ₄ H = Na ₂ S ₂ O ₃ K/E = Zn AcNaOH O = Other		Container Code P = Plastic A = Amber Glass V = Vial G = Glass B = Bacteria Cup C = Cube O = Other E = Encore D = BOD Bottle		Westboro: Certification No: MA935 Mansfield: Certification No: MA015		Container Type Preservative	
Relinquished By: AR 3/17 9:00 3/17 13:30 3/17 3:17		Date/Time 3/17 9:00 3/17 13:30 3/17 3:17		Received By: AR 3/17 9:00 3/17 13:30 3/17 3:17		Date/Time 3/17 9:00 3/17 13:30 3/17 3:17	
Form No: 01-14 HC (rev. 30-Sept-2013)		Form No: 01-14 HC (rev. 30-Sept-2013)		Form No: 01-14 HC (rev. 30-Sept-2013)		Form No: 01-14 HC (rev. 30-Sept-2013)	

Page 133 of 133