

## Sample Summary

**Partner Engineering & Science**

**Job No: JC39209**

**Holman Elementary, 125 Manhattan Street, Jackson, NJ**

Sample Number	Collected		Received	Matrix		Client Sample ID
	Date	Time By		Code	Type	
JC39209-1	03/19/17	06:18 MG	03/20/17	DW	Drinking Water FB	HES-FIELD BLANK
JC39209-2	03/19/17	06:28 MG	03/20/17	DW	Drinking Water	HES-POE
JC39209-4	03/19/17	06:36 MG	03/20/17	DW	Drinking Water	HES-WF-01
JC39209-6	03/19/17	06:39 MG	03/20/17	DW	Drinking Water	HES-WF-02
JC39209-8	03/19/17	06:42 MG	03/20/17	DW	Drinking Water	HES-WF-03
JC39209-10	03/19/17	06:48 MG	03/20/17	DW	Drinking Water	HES-WF-04
JC39209-12	03/19/17	06:57 MG	03/20/17	DW	Drinking Water	HES-S-05
JC39209-14	03/19/17	06:56 MG	03/20/17	DW	Drinking Water	HES-S-06
JC39209-16	03/19/17	07:01 MG	03/20/17	DW	Drinking Water	HES-WF-07
JC39209-18	03/19/17	07:08 MG	03/20/17	DW	Drinking Water	HES-WF-08
JC39209-20	03/19/17	07:12 MG	03/20/17	DW	Drinking Water	HES-WF-09
JC39209-22	03/19/17	07:16 MG	03/20/17	DW	Drinking Water	HES-WF-10
JC39209-24	03/19/17	07:22 MG	03/20/17	DW	Drinking Water	HES-WF-11

## Sample Summary (continued)

**Partner Engineering & Science**

**Job No: JC39209**

**Holman Elementary, 125 Manhattan Street, Jackson, NJ**

Sample Number	Collected		Received	Matrix		Client Sample ID
	Date	Time By		Code	Type	
JC39209-26	03/19/17	07:24 MG	03/20/17	DW	Drinking Water	HES-WF-12
JC39209-28	03/19/17	07:39 MG	03/20/17	DW	Drinking Water	HES-S-13
JC39209-30	03/19/17	07:43 MG	03/20/17	DW	Drinking Water	HES-WF-14
JC39209-32	03/19/17	07:47 MG	03/20/17	DW	Drinking Water	HES-WF-15
JC39209-34	03/19/17	07:53 MG	03/20/17	DW	Drinking Water	HES-WF-16
JC39209-36	03/19/17	07:56 MG	03/20/17	DW	Drinking Water	HES-WF-17
JC39209-38	03/19/17	08:00 MG	03/20/17	DW	Drinking Water	HES-WF-18
JC39209-40	03/19/17	08:04 MG	03/20/17	DW	Drinking Water	HES-WF-19
JC39209-42	03/19/17	08:06 MG	03/20/17	DW	Drinking Water	HES-WF-20
JC39209-44	03/19/17	08:09 MG	03/20/17	DW	Drinking Water	HES-WF-21
JC39209-46	03/19/17	08:12 MG	03/20/17	DW	Drinking Water	HES-WF-22
JC39209-48	03/19/17	08:19 MG	03/20/17	DW	Drinking Water	HES-S-23
JC39209-50	03/19/17	08:23 MG	03/20/17	DW	Drinking Water	HES-WF-24

## Sample Summary (continued)

**Partner Engineering & Science**

**Job No: JC39209**

**Holman Elementary, 125 Manhattan Street, Jackson, NJ**

Sample Number	Collected		Received	Matrix		Client Sample ID
	Date	Time By		Code	Type	
JC39209-52	03/19/17	08:26 MG	03/20/17	DW	Drinking Water	HES-WF-25
JC39209-54	03/19/17	08:29 MG	03/20/17	DW	Drinking Water	HES-WF-26
JC39209-56	03/19/17	08:32 MG	03/20/17	DW	Drinking Water	HES-WF-27
JC39209-58	03/19/17	08:37 MG	03/20/17	DW	Drinking Water	HES-WF-28
JC39209-60	03/19/17	08:43 MG	03/20/17	DW	Drinking Water	HES-WF-29
JC39209-62	03/19/17	08:45 MG	03/20/17	DW	Drinking Water	HES-WF-30
JC39209-64	03/19/17	08:47 MG	03/20/17	DW	Drinking Water	HES-WF-31
JC39209-66	03/19/17	08:51 MG	03/20/17	DW	Drinking Water	HES-WF-32
JC39209-68	03/19/17	08:54 MG	03/20/17	DW	Drinking Water	HES-WF-33
JC39209-70	03/19/17	08:57 MG	03/20/17	DW	Drinking Water	HES-WF-34
JC39209-72	03/19/17	08:59 MG	03/20/17	DW	Drinking Water	HES-WF-35
JC39209-74	03/19/17	09:02 MG	03/20/17	DW	Drinking Water	HES-WF-36
JC39209-76	03/19/17	09:05 MG	03/20/17	DW	Drinking Water	HES-S-37

**Sample Summary**  
(continued)

**Partner Engineering & Science**

**Job No: JC39209**

**Holman Elementary, 125 Manhattan Street, Jackson, NJ**

<b>Sample Number</b>	<b>Collected Date</b>	<b>Time By</b>	<b>Received</b>	<b>Matrix Code</b>	<b>Type</b>	<b>Client Sample ID</b>
JC39209-78	03/19/17	09:10 MG	03/20/17	DW	Drinking Water	HES-WF-38
JC39209-80	03/19/17	09:12 MG	03/20/17	DW	Drinking Water	HES-WF-39
JC39209-82	03/19/17	09:19 MG	03/20/17	DW	Drinking Water	HES-WF-40
JC39209-84	03/19/17	09:25 MG	03/20/17	DW	Drinking Water	HES-WF-41
JC39209-86	03/19/17	09:29 MG	03/20/17	DW	Drinking Water	HES-WF-42

## Report of Analysis

<b>Client Sample ID:</b> HES-FIELD BLANK		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-1		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water FB		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99378

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-POE		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-2		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00340	0.015	0.00050	mg/l	1	03/22/17	03/23/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41630

(2) Prep QC Batch: MP99256

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-01		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-4		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99378

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-02		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-6		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99378

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-03		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-8		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99378

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-04		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-10		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99378

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-S-05		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-12		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00355	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99378

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-S-06		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-14		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00355	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99378

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-07		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-16		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99378

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-08		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-18		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99379

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-09		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-20		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99379

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-10		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-22		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99379

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-11		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-24		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00258	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99379

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-12		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-26		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00645	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99379

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-S-13		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-28		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00120	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99379

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-14		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-30		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00375	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99379

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-15		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-32		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00358	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99379

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-16		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-34		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00600	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99379

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-17		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-36		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00270	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99379

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-18		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-38		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00536	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99380

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-19		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-40		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00243	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99380

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-20		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-42		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00357	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99380

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-21		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-44		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00447	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99380

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-22		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-46		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00526	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99380

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-S-23		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-48		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00867	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99380

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-24		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-50		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00448	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99380

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-25		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-52		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00346	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99380

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-26		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-54		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00222	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99380

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-27		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-56		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00304	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99380

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-28		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-58		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00220	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99381

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-29		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-60		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00420	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99381

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-30		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-62		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00264	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99381

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-31		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-64		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00459	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99381

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-32		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-66		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00279	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99381

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-33		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-68		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00123	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99381

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-34		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-70		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00247	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99381

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-35		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-72		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00118	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99381

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-36		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-74		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00189	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99381

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-S-37		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-76		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00380	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99381

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-38		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-78		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00174	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99410

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-39		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-80		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00427	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99410

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-40		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-82		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00297	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99410

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-41		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-84		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	0.00366	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99410

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)

## Report of Analysis

<b>Client Sample ID:</b> HES-WF-42		<b>Date Sampled:</b> 03/19/17
<b>Lab Sample ID:</b> JC39209-86		<b>Date Received:</b> 03/20/17
<b>Matrix:</b> DW - Drinking Water		<b>Percent Solids:</b> n/a
<b>Project:</b> Holman Elementary, 125 Manhattan Street, Jackson, NJ		

**Total Metals Analysis**

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Lead	< 0.00050	0.015	0.00050	mg/l	1	03/22/17	03/22/17 MA	EPA 200.8 <sup>1</sup>	EPA 200.8 <sup>2</sup>

(1) Instrument QC Batch: MA41626

(2) Prep QC Batch: MP99410

---

RL = Reporting Limit  
MCL = Maximum Contamination Level (NJAC 7:10 11/04)



ACCUTEST

DW  
FB

CHAIN OF CUSTODY

2235 Route 130, Dayton, NJ 08810  
TEL. 732-329-0200 FAX: 732-329-3499/3480  
www.accutest.com

FED-EX Tracking #	Bottle Order Control #
Accutest Quote #	Accutest Job # <b>JC39209</b>

Client / Reporting Information		Project Information				Requested Analysis ( see TEST CODE sheet)												Matrix Codes		
Company Name <b>Partner Engineering and Science, Inc</b>		Project Name: <b>Holman Elementary</b>				PBMS, TURBIDIMET												DW - Drinking Water GW - Ground Water WW - Water SW - Surface Water SO - Soil SL - Sludge SED - Sediment OI - Oil LIQ - Other Liquid AIR - Air SOL - Other Solid WIP - Wipe FB - Field Blank EB - Equipment Blank RB - Rinse Blank TB - Trip Blank		
Street Address <b>611 Industrial Way West</b>		Street <b>125 Manhattan St</b>		Billing Information ( if different from Report to)																
City <b>Eaton town NJ</b>		City <b>Jackson NJ</b>		Company Name																
Project Contact <b>Matt Genna</b>		Project #		Street Address																
Phone # <b>732-390-1700</b>		Client Purchase Order #		City State Zip																
Sampler(s) Name(s) <b>Michelle Gomez</b>		Phone #		Project Manager		Attention:														
Accutest Sample #	Field ID / Point of Collection	MEOH/CI Vial #	Date	Time	Sampled by	Matrix	# of bottles	HCl	NaOH	HN03	H2SO4	HNO2	DI Water	MEQH	ENCORE	LAB USE ONLY				
1	HES-FIELD BLANK		3/19/17	6:18	Mb	DFB	1									X	A35			
2	HES-POE			6:28		DW	1									X				
3	HES-POE FLUSH			6:29		DW	1									X				
4	HES-WF-01			6:36		DW	1									X				
5	HES-WF-01 FLUSH			6:37		DW	1									X				
6	HES-WF-02			6:39		DW	1									X				
7	HES-WF-02 FLUSH			6:40		DW	1									X				
8	HES-WF-03			6:42		DW	1									X				
9	HES-WF-03 FLUSH			6:43		DW	1									X				
10	HES-WF-04 FLUSH			6:48		DW	1									X	INITIAL ASSESSMENT			
11	HES-WF-04 FLUSH			6:49		DW	1									X	LABEL VERIFICATION			
12	HES-S-05			6:54		DW	1									X				

Turnaround Time ( Business days)		Approved By (Accutest PM): / Date:		Data Deliverable Information				Comments / Special Instructions			
<input type="checkbox"/> Std. 10 Business Days <input checked="" type="checkbox"/> 5 Day RUSH <input type="checkbox"/> 3 Day RUSH <input type="checkbox"/> 2 Day RUSH <input type="checkbox"/> 1 Day RUSH <input type="checkbox"/> other				<input type="checkbox"/> Commercial "A" ( Level 1) <input type="checkbox"/> Commercial "B" ( Level 2) <input type="checkbox"/> FULLT1 ( Level 3+4) <input checked="" type="checkbox"/> NJ Reduced <input type="checkbox"/> Commercial "C" <input type="checkbox"/> NJ Data of Known Quality Protocol Reporting				<input type="checkbox"/> NYASP Category A <input type="checkbox"/> NYASP Category B <input type="checkbox"/> State Forms <input type="checkbox"/> EDD Format <input type="checkbox"/> Other			
Emergency & Rush T/A data available VIA Lablink				Commercial "A" = Results Only, Commercial "B" = Results + QC Summary NJ Reduced = Results + QC Summary + Partial Raw data				<b>LOG IN QACHECK &amp; PMCHECK</b> Program code: PAK1DWWPB FLUSH SAMPLES ON HOLD!			

Sample Custody must be documented below each time samples change possession, including courier delivery.

Relinquished by Sampler: <b>Michelle Gomez</b>	Date Time: <b>3/19/17</b>	Received By: <b>David Rank</b>	Date Time: <b>3:00</b>	Relinquished By: <b>David Rank</b>	Date Time: <b>3:00</b>	Received By: <b>[Signature]</b>
Relinquished by Sampler:	Date Time:	Received By:	Date Time:	Relinquished By:	Date Time:	Received By:
Relinquished by:	Date Time:	Received By:	Date Time:	Custody Seal: <b>622</b>	Intact <input checked="" type="checkbox"/>	Not Intact <input type="checkbox"/>

On Ice  Cooler Temp. **2.7°C / 39.0°F**

JC39209: Chain of Custody



ACCUTEST

CHAIN OF CUSTODY

2235 Route 130, Dayton, NJ 08810
TEL: 732-329-0200 FAX: 732-329-3499/3480
www.accutest.com

FED-EX Tracking #
Bottle Order Control #
Accutest Quote #
Accutest Job # JC39209

Client / Reporting Information
Project Information
Requested Analysis (see TEST CODE sheet)
Matrix Codes
Company Name: Partner Engineering and Science, Inc
Project Name: Holman Elementary
Street: 125 Manhattan St
City: Jackson NJ
State: NJ
City: Eatontown NJ
Project Contact: Matt Genna
Phone # 732-380-1700
Sampler(s) Name(s): Michelle Gomez
Collection table with columns: Accutest Sample #, Field ID / Point of Collection, MECHDI Vial #, Date, Time, Sampled by, Matrix, # of bottles, and various chemical parameters (Pb, Ni, Hg, etc.).
Turnaround Time (Business days)
Data Deliverable Information
Comments / Special Instructions: LOG IN QACHECK & PMCHECK, Program code: PAK1DWPB, FLUSH SAMPLES ON HOLD!
Sample Custody must be documented below each time samples change possession, including courier delivery. 12:40
Relinquished by: Michelle Gomez, Date Time: 3/19/17
Received By: [Signature], Date Time: 3:20:17

JC39209: Chain of Custody



ACCUTEST

CHAIN OF CUSTODY

2235 Route 130, Dayton, NJ 08810
TEL. 732-329-0200 FAX. 732-329-3499/3480
www.accutest.com

FED-EX Tracking #
Bottle Order Control #
Accutest Quote #
Accutest Job # JC39209

Client / Reporting Information
Project Information
Requested Analysis (see TEST CODE sheet)
Matrix Codes
Company Name: Partner Engineering and Science, Inc
Project Name: Holman Elementary
Street Address: 611 Industrial Way West
City: Eatontown NJ
Project Contact: Matt Genna
Phone #: 732-380-1700
Sampler(s) Name(s): Michelle Gomez
Project Manager: Michelle Gomez
Collection table with columns: Field ID / Point of Collection, MEQ/MDI Vial #, Date, Time, Sampled by, Matrix, # of bottles, HCl, H2SO4, HNO3, NONE, DI Water, H2O2, H2O, ENCORE. Rows 25-36 show samples 25-36 with dates around 3/19/17 and times around 7:23-7:56.

Turnaround Time (Business days)
Data Deliverable Information
Comments / Special Instructions
LOG IN QACHECK & PMCHECK
Program code: PAR1DWPB
FLUSH SAMPLES ON HOLD!

Sample Custody must be documented below each time samples change possession, including courier delivery. 12:40
Relinquished by: Michelle Gomez
Date Time: 3/19/17
Received By: Michelle Gomez
Date Time: 3:20:17
Relinquished by: Michelle Gomez
Date Time: 3
Received By: Michelle Gomez
Date Time: 4
Relinquished by: Michelle Gomez
Date Time: 5
Received By: Michelle Gomez
Date Time: 5
Intact/Not intact, Preserved where applicable, On Ice, Cooler Temp.

JC39209: Chain of Custody





ACCUTEST

CHAIN OF CUSTODY

2235 Route 130, Dayton, NJ 08810
TEL: 732-329-0200 FAX: 732-329-3499/3480
www.accutest.com

FED-EX Tracking #
Bottle Order Control #
Accutest Quote #
Accutest Job # JC39209

Table with columns: Client / Reporting Information, Project Information, Requested Analysis, Matrix Codes, and LAB USE ONLY. Includes sample details for HES-S-23 FLUSH through HES-WF-29.

Turnaround Time (Business days)
Data Deliverable Information
Comments / Special Instructions
LOG IN QACHECK & PMCHECK
Program code: PAK1DWPB
FLUSH SAMPLES ON HOLD!

Table for Chain of Custody with columns: Relinquished by Sampler, Date Time, Received By, Date Time, Relinquished By, Date Time, Received By, Date Time. Includes handwritten signatures and dates.



ACCUTEST

CHAIN OF CUSTODY

2235 Route 130, Dayton, NJ 08810
TEL 732-329-0200 FAX: 732-329-3499/3480
www.accutest.com

FED-EX Tracking #
Bottle Order Control #
Accutest Quote #
Accutest Job # JC39209

Client / Reporting Information
Project Information
Requested Analysis (see TEST CODE sheet)
Matrix Codes
Company Name: Partner Engineering and Science, Inc
Project Name: Holman Elementary
Street: 611 Industrial Way West
City: Eatontown NJ
Project Contact: Matt Genna
Phone #: 732-380-1700
Sampler(s) Name(s): Michelle Gomez
Collection table with columns: Date, Time, Sampled by, Matrix, # of bottles, HCl, MICH, HNO3, H2SO4, NONE, DI Water, MICH, ENCORE, PBMS, TURBIDIMET, LAB USE ONLY

Turnaround Time (Business days)
Data Deliverable Information
Comments / Special Instructions
LOG IN QACHECK & PMCHECK
Program code: PAK1DWP15
FLUSH SAMPLES ON HOLD!

Sample Custody must be documented below each time samples change possession, including courier delivery. 12:40
Relinquished by Sampler: Michelle Gomez
Date Time: 3/19/17
Received By: [Signature]
Date Time: 3/20/17
Received By: [Signature]

JC39209: Chain of Custody



ACCUTEST

CHAIN OF CUSTODY

2235 Route 130, Dayton, NJ 08810
TEL: 732-329-0200 FAX: 732-329-3499/3480
www.accutest.com

Table with 2 columns: FED-EX Tracking #, Bottle Order Control #; Accutest Quote #, Accutest Job # (JC39209)

Main form containing Client/Reporting Information, Project Information, Requested Analysis, Matrix Codes, and a table of Accutest Samples (73-84) with collection dates and times.

Turnaround Time (Business days), Data Deliverable Information, and Comments/Special Instructions section.

Chain of Custody table with columns for Relinquished by, Date Time, Received By, and Date Time, including handwritten signatures and dates.

JC39209: Chain of Custody

Page 7 of 9



ACCUTEST

CHAIN OF CUSTODY

2235 Route 130, Dayton, NJ 08810
TEL: 732-329-0200 FAX: 732-329-3499/3480
www.accutest.com

FED-EX Tracking #
Bottle Order Control #
Accutest Quote #
Accutest Job # JC39209

Client / Reporting Information
Project Information
Requested Analysis (see TEST CODE sheet)
Matrix Codes
LAB USE ONLY
Turnaround Time (Business days)
Data Deliverable Information
Comments / Special Instructions
LOG IN QACHECK & PMCHECK
Program code: PAK1UWPP
FLUSH SAMPLES ON HOLD!
Relinquished by: Michelle Gomez
Date Time: 3/19/17
Received By: Debra...
Date Time: 3/20/17

JC39209: Chain of Custody

## SGS Accutest Sample Receipt Summary

Job Number: JC39209

Client: \_\_\_\_\_

Project: \_\_\_\_\_

Date / Time Received: 3/20/2017 12:40:00 PM

Delivery Method: \_\_\_\_\_

Airbill #'s: \_\_\_\_\_

Cooler Temps (Raw Measured) °C: Cooler 1: (2.7); Cooler 2: (3.9); Cooler 3: (4.0);

Cooler Temps (Corrected) °C: Cooler 1: (4.1); Cooler 2: (5.3); Cooler 3: (5.4);

<u>Cooler Security</u>	<u>Y or N</u>			<u>Y or N</u>	
1. Custody Seals Present:	<input checked="" type="checkbox"/>	<input type="checkbox"/>	3. COC Present:	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2. Custody Seals Intact:	<input checked="" type="checkbox"/>	<input type="checkbox"/>	4. Smpl Dates/Time OK	<input checked="" type="checkbox"/>	<input type="checkbox"/>

<u>Cooler Temperature</u>	<u>Y or N</u>	
1. Temp criteria achieved:	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2. Cooler temp verification:	<u>IR Gun</u>	
3. Cooler media:	<u>Ice (Bag)</u>	
4. No. Coolers:	<u>3</u>	

<u>Quality Control Preservation</u>	<u>Y</u>	<u>or</u>	<u>N</u>	<u>N/A</u>
1. Trip Blank present / cooler:	<input type="checkbox"/>		<input checked="" type="checkbox"/>	<input type="checkbox"/>
2. Trip Blank listed on COC:	<input type="checkbox"/>		<input checked="" type="checkbox"/>	<input type="checkbox"/>
3. Samples preserved properly:	<input checked="" type="checkbox"/>		<input type="checkbox"/>	
4. VOCs headspace free:	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>

<u>Sample Integrity - Documentation</u>	<u>Y</u>	<u>or</u>	<u>N</u>
1. Sample labels present on bottles:	<input checked="" type="checkbox"/>		<input type="checkbox"/>
2. Container labeling complete:	<input checked="" type="checkbox"/>		<input type="checkbox"/>
3. Sample container label / COC agree:	<input checked="" type="checkbox"/>		<input type="checkbox"/>

<u>Sample Integrity - Condition</u>	<u>Y</u>	<u>or</u>	<u>N</u>
1. Sample recvd within HT:	<input checked="" type="checkbox"/>		<input type="checkbox"/>
2. All containers accounted for:	<input checked="" type="checkbox"/>		<input type="checkbox"/>
3. Condition of sample:	<u>Intact</u>		

<u>Sample Integrity - Instructions</u>	<u>Y</u>	<u>or</u>	<u>N</u>	<u>N/A</u>
1. Analysis requested is clear:	<input checked="" type="checkbox"/>		<input type="checkbox"/>	
2. Bottles received for unspecified tests	<input type="checkbox"/>		<input checked="" type="checkbox"/>	
3. Sufficient volume recvd for analysis:	<input checked="" type="checkbox"/>		<input type="checkbox"/>	
4. Compositing instructions clear:	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>
5. Filtering instructions clear:	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>

Comments

SM089-02  
Rev. Date 12/1/16

**JC39209: Chain of Custody**

**Page 9 of 9**